

March 25, 2020

Chris Epkins
Operations Assistant
Illinois Oil Marketing Equipment

RE: Fuel Compatibility

This letter is in reference to the following site:

#775 Loves Rockford
US20 & Main St
Rockford, IL 61101

Parts and equipment listed are to have been manufactured within calendar year of this letter.

This letter affirms that the list of referenced equipment below is compatible with the following fuels:

Bio Diesel up to 5% B5
Bio Diesel up to 20% B20
Bio Diesel at 97%-100% B99/B100
All ASTM Biofuel blends

Compatible equipment/models:

TSP-LL2-XXX-I (using TSP-SSP Float Only)
FMP-LL3-XXX-I (using TSP-SSP Float Only)
TSP-ULS-C
TSP- DIS, FMP-DIS, FMP-DIS-U (dry interstitial applications only)
TSP-EIS, FMP-EIS, FMP-EIS-U (dry interstitial applications only)

Sincerely



Loren Swalheim



Director, Global Technical Services
Franklin Fueling System