

**Blended Fuel Compatibility Form**

Facility - 2010827

**Facility Name** BP  
**Address** 2405 West Augusta  
Chicago, IL 60622  
**County** Cook  
**Contact Name** Kadar Sodagar  
**Phone Number** (773) 616-4838

Tank - 8

**Tank Material** Tank - Composite Double  
Wall Modern Welding Glasteel  
II  
**Tank Capacity** 3,000  
**Tank Product** E15  
**Tank Install Date** Not Installed

**Tank Equipment**

| Compatibility Item    | Model/Manufacturer         | Compatibility Method  | Documentation                               | Comment                      |
|-----------------------|----------------------------|-----------------------|---------------------------------------------|------------------------------|
| Composite Double Wall | Modern Welding Glasteel II | Manufacturer Approval | Glasteel II BioFuels Compatibility 2018.pdf | New from Permit Application. |

**Piping Equipment**

| Compatibility Item   | Model/Manufacturer | Compatibility Method  | Documentation                        | Comment                      |
|----------------------|--------------------|-----------------------|--------------------------------------|------------------------------|
| Flexible Double Wall | NUPI Smartflex     | Manufacturer Approval | NUPI UL LETTER - COMPATIBILITY.pdf   | New from Permit Application. |
| Shear Valve          | OPW 10 PLUS        | Manufacturer Approval | OPW 10 Plus Impact Compatibility.pdf |                              |

**Containment Sump Equipment**

| Compatibility Item           | Model/Manufacturer | Compatibility Method  | Documentation                          | Comment                      |
|------------------------------|--------------------|-----------------------|----------------------------------------|------------------------------|
| Single Wall STP/Tanktop Sump | BRAVO B410         | Manufacturer Approval | Bravo Sump Compatibility Statement.pdf | New from Permit Application. |
| Not Installed UDC Sump       | NUPI HDPE          | Manufacturer Approval | NUPI UL LETTER - COMPATIBILITY.pdf     |                              |

**Release Detection Tank Equipment**

| Compatibility Item                                 | Model/Manufacturer     | Compatibility Method  | Documentation                                  | Comment                      |
|----------------------------------------------------|------------------------|-----------------------|------------------------------------------------|------------------------------|
| Non-Discriminating Interstitial Monitoring Sensors | VEEDER ROOT 794380-430 | Manufacturer Approval | Veeder Root Sensor Compatibility Statement.pdf | New from Permit Application. |
| ATG Probe                                          | VEEDER ROOT 846391-107 | Manufacturer Approval | Veeder Root E85 probe 577 013-054.pdf          |                              |

**Release Detection Piping Equipment**

| Compatibility Item                         | Model/Manufacturer     | Compatibility Method  | Documentation                                  | Comment                      |
|--------------------------------------------|------------------------|-----------------------|------------------------------------------------|------------------------------|
| Electronic Pressurized Line Leak Detection | VEEDER ROOT PLLD       | Manufacturer Approval | Veeder Root PLLD.pdf                           | New from Permit Application. |
| Sump Sensor with positive shutdown         | VEEDER ROOT 794380-323 | Manufacturer Approval | Veeder Root Sensor Compatibility Statement.pdf | New from Permit Application. |

**Spill Prevention Equipment**

| Compatibility Item       | Model/Manufacturer | Compatibility Method  | Documentation                                                    | Comment                      |
|--------------------------|--------------------|-----------------------|------------------------------------------------------------------|------------------------------|
| Double Wall Spill Bucket | FRANKLIN DEFENDER  | Manufacturer Approval | FE PETRO DEFENDER ffs-013 0-defender-series-brochure-713-web.pdf | New from Permit Application. |

### Overfill Prevention Equipment

| Compatibility Item       | Model/Manufacturer | Compatibility Method  | Documentation                                              | Comment                      |
|--------------------------|--------------------|-----------------------|------------------------------------------------------------|------------------------------|
| Overfill Drop Tube Valve | OPW 71SOM          | Manufacturer Approval | OPW Belowground Product C ompatibility Listing 0715 18.pdf | New from Permit Application. |

### Pump Equipment

| Compatibility Item       | Model/Manufacturer | Compatibility Method  | Documentation                                      | Comment |
|--------------------------|--------------------|-----------------------|----------------------------------------------------|---------|
| Submersible Turbine Pump | FE PETRO STP AG    | Manufacturer Approval | FE Petro STP Compatibilit y Statement.pdf          |         |
| Dispenser                | WAYNE OVATION      | Manufacturer Approval | ul-approval-letter-ovatio n-blender-dispensers.pdf |         |
| Nozzle                   | OPW 11BP           | Manufacturer Approval | OPW 11a-and-11b- automatic -nozzles.pdf            |         |
| Hose                     | GOODYEAR           | Manufacturer Approval | Goodyear E85 Ethanol hose .pdf                     |         |

### Gaskets & Seals Equipment

| Compatibility Item | Model/Manufacturer | Compatibility Method | Documentation | Comment |
|--------------------|--------------------|----------------------|---------------|---------|
| NA                 | NA                 | Not Applicable       |               | NA      |

### Joint Dopes & Adhesives Equipment

| Compatibility Item | Model/Manufacturer | Compatibility Method  | Documentation      | Comment |
|--------------------|--------------------|-----------------------|--------------------|---------|
| PIPE DOPE          | GASOILA E SEAL     | Manufacturer Approval | Gasoila E-Seal.pdf |         |

#### Correspondence Contact

**Submitter Name** CHRIS DERRO

**Job Title** PRESIDENT

**Company** Cardinal Compliance LLC

**Phone Number** (708) 717-2676

**Email** CDERRO@CARDINALCOMPLIANCE.NET

**Contractor License #** IL002418

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.