



Blended Fuel Compatibility Form

Facility - 1042306

Facility Name	Love's Travel Stop #322
Address	13477 Quality Drive Roscoe, IL 61073
County	Winnebago
Contact Name	Tim Linch
Phone Number	(815) 389-1923

Tank - 2

Tank Material	Composite Double Wall
Tank Capacity	20,000
Tank Product	B-99
Tank Install Date	8/19/2004

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Composite Double Wall	Glasteel II	Manufacturer Approval	BioFuels Compatibility 2018.pdf	

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Ameron Dualoy 3000/LCX	Manufacturer Approval	Dualoy+3000+LCX+Data+Sheet B99 & E85.pdf	

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	Advanced Containment	Manufacturer Approval	GSG+CSI+compat.pdf	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
ATG Probe	Veeder-Root	Manufacturer Approval	577014-449-08_Stainless_Steel_Mag_Plus_In-Tank_Probe_Alternative_Fluids.pdf	
Non-Discriminating Interstitial Monitoring Sensors	Veeder-Root	Manufacturer Approval	V-R_794380-345_Intersitia ISensor.pdf	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder-Root	Manufacturer Approval	V-R_848480-003_PLLD.pdf	
Non-Discriminating Sump Sensor in Single Wall STP/Tanktop Sump	Veeder-Root	Manufacturer Approval	577013-750-17_NonDiscriminatingMicroSensor_1 B99 & E85.pdf	

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	OPW	Manufacturer Approval	opw-fuel-compatibility-be low-ground-products-2018.pdf	

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Alarm	Veeder-Root	Manufacturer Approval	576047-241_Overfill_Alarm .pdf	
Overfill Drop Tube Valve	Franklin Fueling Systems	Manufacturer Approval	FFS-0392 Defender Series OPV Datasheet B99.pdf	

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
STP	Veeder-Root / Red Jacket	Manufacturer Approval	!!!Veeder-Root - Fuel Compatibility Letter - Executed - 2015-09-23 (2).pdf	

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name	Zachary Cooley	<input checked="" type="checkbox"/> By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.
Job Title	Project Manager	
Company	Illinois Oil Marketing Equipment	
Phone Number	(309) 253-5281	
Email	zcooley@iome.com	
Contractor License #	IL1293	