

**Blended Fuel Compatibility Form**

Facility - 2017681

Facility Name Michigan Citgo
Address 11600 S. Michigan Ave.
Chicago, IL 60628
County Cook
Contact Name Haney Khalil
Phone Number (773) 785-0932

Tank - 3

Tank Material Steel Single Wall
Tank Capacity 12,000
Tank Install Date 3/17/1969
Current Product on File Gasoline - Regular
Newly Reported Product E-85

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Steel Single Wall	Steel	Manufacturer Approval	highland-tank.pdf	

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Flexible Double Wall	A.P.T. XP	Manufacturer Approval	Franklin FFS-0524 XP Flexible Pipework Datasheet.pdf	

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	Franklin Fueling, TSM-4245	Manufacturer Approval	APT Sumps E85 Compatibility Letter 08.07.19.pdf	
Single Wall Dispenser Sump	Franklin Fueling	Manufacturer Approval	APT Sumps E85 Compatibility Letter 08.07.19.pdf	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
ATG Probe	Veeder Root, 846391-507	Manufacturer Approval	veeder root probes.pdf	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Mechanical Pressurized Line Leak Detection	Franklin 403169901	Manufacturer Approval	franklin mllid.pdf	

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	OPW 1-2100EVR	Manufacturer Approval	Opw spill containers.pdf	

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW 71SOM-412C	Manufacturer Approval	71SOM_Overfill_Prevention_Valve.pdf	

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible Pump	Franklin 4020159	Manufacturer Approval	franklin stp.pdf	
Dispenser	Wayne EB23/5220D3	Manufacturer Approval	wayne dispensers all.pdf	

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact		☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.
Submitter Name	Ed Angell	
Job Title	Project Manager	
Company	B&K Equipment Company	
Phone Number	(708) 474-3344	
Email	ed@bkequip.com	
Contractor License #	IL1207	