

**Blended Fuel Compatibility Form**

Facility - 3034795		Tank - 4	
Facility Name	Fuel 24	Tank Material	Fiberglass Single Wall
Address	7814 N. Kickapoo Edwards, IL 61528	Tank Capacity	12,000
County	Peoria	Tank Product	B-99
Contact Name	John Papenhouse	Tank Install Date	10/19/2006
Phone Number	(309) 208-8105		

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Single Wall	Containment Solutions	Manufacturer Approval		

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Aboveground	steel pipe	Not Applicable		all piping for bio is above ground
Shear Valve	no shear valves	Not Applicable		no shear valves

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Not Installed STP/Tanktop Sump	no stp sumps	Not Applicable		STP DO NOT HAVE A SUMP, THEY ARE ABOVE GROUND

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
TLS350	VEEDER ROOT	Manufacturer Approval		
ATG Probe	VEEDER ROOT/846396	Manufacturer Approval		

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Other Aboveground Piping	ABOVE GROUND STEEL PIPE	Not Applicable		ABOVE GROUND PIPING NO RELEASE DET

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket West remote fill	MORRISON/516	Manufacturer Approval		
Single Wall Spill Bucket East	MORRISON/516	Manufacturer Approval		

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Alarm	VEEDER ROOT/846396 PROBE	Manufacturer Approval		

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible Turbine Pump	THE RED JACKET ALCOHOL GAS (AG) STP	Manufacturer Approval		

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact		☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.
Submitter Name	John Papenhouse	
Job Title	energy consultant	
Company	Ag-Land FS Inc	
Phone Number	(309) 208-8105	
Email	jpapenhouse@aglandfs.com	