



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL

Blended Fuel Compatibility Form

Facility - 3024714

Facility Name Huck's #249
Address 7225 N. Allen Road
Peoria, IL 61607
County Peoria
Contact Name Kenny Haun
Phone Number (309) 692-2403

Tank - 5

Tank Material Fiberglass Double Wall
Tank Capacity 15,000
Tank Install Date 5/14/2014
Current Product on File Gasoline - Regular
Newly Reported Product E15

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	XERXES	Manufacturer Approval		

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Flexible Double Wall	A.P.T. Poly Tech P175SC	Manufacturer Approval		
Shear Valve	OPW OPW10P0152	Manufacturer Approval		

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump East	Xerxes 4236	Manufacturer Approval		
Single Wall STP/Tanktop Sump West	Xerxes 4236	Manufacturer Approval		
Single Wall UDC Sump	OPWFWFDS4021	Manufacturer Approval		

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensors	Veeder Root Model 794390-409	Manufacturer Approval		
ATG Probe	VEE846390109	Manufacturer Approval		

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Mechanical Pressurized Line Leak Detection East	FE Petro STP-MLD 200VL2	Manufacturer Approval		
Mechanical Pressurized Line Leak Detection West	FE Petro STP-MLD 200VL2	Manufacturer Approval		
Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump East	Veeder Root VEE85908002	Manufacturer Approval		
Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump West	Veeder Root VEE85908002	Manufacturer Approval		

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	OPW 1C3112P	Manufacturer Approval		

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW 71SO	Manufacturer Approval		

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible Turbine Pump	OPW 61TP	Manufacturer Approval		
Suction Pump	OPW 61TP	Manufacturer Approval		
Dispenser	Gilbarco Encor 700S	Manufacturer Approval		
Nozzle	Gilbarco 700	Manufacturer Approval		
Hose	Husky 15955904	Manufacturer Approval		

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name Paulette Hosick
Job Title Director of Petroleum
Company Martin & Bayley, Inc dba
Hucks
Phone Number (618) 382-2334
Email phosick@hucks.com

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.