



Blended Fuel Compatibility Form

Facility - 5012161		Tank - 6	
Facility Name	Qik-N-EZ	Tank Material	Composite Single Wall
Address	1101 Stevenson Drive Springfield, IL 62703	Tank Capacity	15,000
County	Sangamon	Tank Product	E-15
Contact Name	Anne Needham	Tank Install Date	11/1/2000
Phone Number	(217) 529-0002		

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Composite Single Wall	Glasteel	Manufacturer Approval		

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Flexible Double Wall	Environ Geo Flex	Manufacturer Approval		Please see updated attachment stating UL971 certification and explanation of UL9...
Shear Valves	EBW 662	Manufacturer Approval		

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	Eviron Geo Flex	Manufacturer Approval		
Under Dispenser Containment	Eviron Geoflex Deep Dispenser Sumps	Manufacturer Approval		

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
ATG	Veedor Root TLS 350 with CSLD	Manufacturer Approval		
ATG Probe	Veedor root 846396-207	Manufacturer Approval		

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veedor Root TLS 350 with PLLD	Manufacturer Approval		
Piping Sump Sensors Not Regulated Not Installed in Single Wall STP/Tanktop Sump	Not applicable-sensors do not exist at this time	Not Applicable		Not applicable-sensors do not exist at this time

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	Emco Wheaton A1004	Manufacturer Approval		

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Ball Float Vent Valve	OPW 53VML	Manufacturer Approval		

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Dispenser Pumps	Gilbarco Encore 700s NL1	Manufacturer Approval		
Submersible Pump	Franklin Fueling/FE Petro IST2-17 00100388	Lab Certification		
Hoses	Irpco Steel flex Ultra HD 559N	Manufacturer Approval		Dept. of Energy listing
Nozzle	OPW 11AP	Manufacturer Approval		

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact		<input checked="" type="checkbox"/> By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.
Submitter Name	Heather Hoffman	
Job Title	Facility Services	
Company	Chronister Oil Company	
Phone Number	(337) 660-7749	
Email	heather.hoffman@lincolnlandoil.com	