

**Blended Fuel Compatibility Form****Facility - New**

Facility Name QuiK Trip #7203
Address 1340 May Rd.
Peru, IL 61354
County LaSalle
Contact Name Kyla Rudd
Phone Number (918) 655-7700

Tank - 6

Tank Material Tank - Fiberglass Brine Filled
Double Wall Containment
Solutions
Tank Capacity 18,000
Tank Product B-99
Tank Install Date Not Installed

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Brine Filled Double Wall	Containment Solutions	Manufacturer Approval	Compat CSI Tanks and Sump s.pdf	From Permit Application

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Flexible Double Wall	Franklin Fueling Systems UPP	Manufacturer Approval	Compat FF UPP Piping.pdf	From Permit Application
Flex Connector Steel	Omegaflex	Manufacturer Approval	Compat Omegaflex Connecto rs.pdf	From Permit Application
Shear Valves	OPW/ 10P Series	Manufacturer Approval	Compat. OPW Shear Valve.p df	

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Blending Sump	Petroleum Containment	Manufacturer Approval	Compat Petroleum Containm ent Sumps.pdf	From Permit Application
Single Wall STP/Tanktop Sump	Petroleum Containment	Manufacturer Approval	Compat Petroleum Containm ent Sumps.pdf	From Permit Application

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Hydrostatic Reservoir Interstitial Monitoring Sensors with monitor	Veeder Root/ 794380-304	Manufacturer Approval	Compat VR Sensors.pdf	From Permit Application
ATG Probe	Veeder Root/ 846397-309	Manufacturer Approval	Compat Veeder Root Probe Bio high density.pdf	Attached is VR's only offering for docs on the probe (High Density Bio)

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Sump Sensor with positive shutdown	Veeder Root/ 794380-351	Manufacturer Approval	Compat VR Sensors.pdf	From Permit Application
Electronic Line Leak Detection	Veeder Root	Manufacturer Approval	Compat VR DPLLD.pdf	

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	OPW 1SC-2100DEV	Manufacturer Approval	OPW Edge Double Wall Spill Bucket.pdf	From Permit Application

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	Franklin Fueling/ 708592922	Manufacturer Approval	Compat Franklin Fueling O PV.pdf	From Permit Application

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible Pump	Franklin Fueling/ ISTM2-15	Manufacturer Approval	Compat FE Petro STP.pdf	
Dispenser Sump	Bravo	Manufacturer Approval	Compat Bravo UDC.pdf	
Gilbarco dispenser	Gilbarco NPA/ NPB	Manufacturer Approval	Fuel Compatibility Gilbarco Dispensers.pdf	Dispenser will not be dispensing B99- this is a BIO injection system/application
Hoses	Goodyear Futura	Manufacturer Approval	Compat Goodyear Hoses.pdf	Not dispensing pure bio
Nozzles	OPW- 11B	Manufacturer Approval	Compat OPW Nozzles.pdf	Not dispensing pure bio

Gaskets & Seals Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Pipe Dope	Gasola/ GE16	Manufacturer Approval	Compat. Gasola GE16.pdf	

Joint Dopes & Adhesives Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Pipe Dope	Gasola/ GE16	Manufacturer Approval	Compat. Gasola GE16.pdf	

Correspondence Contact

Submitter Name Glen Davis
Job Title Installer/ Project Manager
Company Seneca Companies, Inc.
Phone Number (563) 340-5216
Email gdavis@senecaco.com
Contractor License # IL598

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.