

**Blended Fuel Compatibility Form**

Facility - 5044615

Facility Name Qik-N-EZ
Address 4401 Wabash Avenue
Springfield, IL 62711
County Sangamon
Contact Name Heather Hoffman
Phone Number (337) 660-7749

Tank - 6

Tank Material Fiberglass Double Wall
Tank Capacity 10,000
Tank Product E85
Tank Install Date 3/5/2010

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Containment Solutions	Manufacturer Approval		

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Flexible Double Wall	A.P.T. Poly Tech P150SC	Manufacturer Approval		
Shear Valve	EBW 662	Manufacturer Approval		

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Transition Sump	The E85 piping does not go thru this sump - this is 87NL piping	Manufacturer Approval		87 piping T's off and runs to E85 dispenser see attached drawing from install WJ...
Single Wall STP/Tanktop Sump	Containment Solutions	Manufacturer Approval		
Single Wall UDC Sump	Franklin APT LMM-3617	Manufacturer Approval		

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensors	Veedor Root 794380-345	Manufacturer Approval		
ATG Probe	Veedor Root 846397-407	Manufacturer Approval		

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Mechanical Pressurized Line Leak Detection	Vaporless Manf. Inc / Model #2000	Manufacturer Approval		
Sump Sensor with positive shutdown in Single Wall Transition Sump	E85 piping does not go thru this sump - it is 87 NL piping	Lab Certification		please see attached drawing from WJ Scott install
Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Veedor Root 794380-323	Manufacturer Approval		

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	EBW 705	Manufacturer Approval		

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Ball Float Vent Valve	EBW 308	Manufacturer Approval		

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible Turbine Pump	FE Petro STP AGR 75	Manufacturer Approval		
Dispenser	Gilbarco Encore 700 NL2 with E85	Manufacturer Approval		
Nozzle	Opw BP E85	Manufacturer Approval		
Hose	Flexsteel 559n	Manufacturer Approval		

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact		☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.
Submitter Name	Heather Hoffman	
Job Title	Facility Services	
Company	Chronister Oil Company	
Phone Number	(337) 660-7749	
Email	heather.hoffman@lincolnlandoil.com	