

**Blended Fuel Compatibility Form**

Facility - 2015861

Facility Name Vision Gas & Food, Inc.
Address 601 Villa Street
Elgin, IL 60120
County Kane
Contact Name Mohammed Amlani
Phone Number (847) 608-1099

Tank - 10

Tank Material Tank - Composite Double
Wall Glasteel II
Tank Capacity 4,000
Tank Product E85
Tank Install Date Not Installed

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Composite Double Wall	Glasteel II	Manufacturer Approval	Glasteel II BioFuels Compatibility 2018.pdf	New from Permit Application.

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Flexible Double Wall	NUPI Smartflex	Manufacturer Approval	NUPI UL LETTER - COMPATIBILITY.pdf	New from Permit Application.
Shear Valve	OPW 10 PLUS	Manufacturer Approval	OPW 10 Plus Impact Compatibility.pdf	

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	BRAVO B410	Manufacturer Approval	Bravo Sump Compatibility Statement.pdf	New from Permit Application.
Single Wall UDC Sump	NUPI SINGLEWALL HDPE	Manufacturer Approval	NUPI UL LETTER - COMPATIBILITY.pdf	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensors	794380-333	Manufacturer Approval	Veeder Root Sensor Compatibility Statement.pdf	New from Permit Application.
ATG Probe	846391-407	Manufacturer Approval	Veeder Root E85 probe 577 013-054.pdf	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Sump Sensor with positive shutdown	794380-323	Manufacturer Approval	Veeder Root Sensor Compatibility Statement.pdf	New from Permit Application.
Mechanical Pressurized Line Leak Detection	403169903	Manufacturer Approval	FE Petro MLD Compatibility.pdf	New from Permit Application.

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	OPW 3100	Manufacturer Approval	OPW Belowground Product Compatibility Listing 0715 18.pdf	New from Permit Application.

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW 71SOM	Manufacturer Approval	OPW 71SOM_Overfill_Prevention_Valve.pdf	New from Permit Application.

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
GAS DISPENSERS	GILBARCO ENCORE	Manufacturer Approval	GILBARCO ENCORE.pdf	
Submersible Turbine Pump	FE PETRO STP AG	Manufacturer Approval	FE Petro STP Compatibility Statement.pdf	
Nozzle	OPW BP	Manufacturer Approval	OPW 11a-and-11b-automatic -nozzles.pdf	
Hose	GOODYEAR	Manufacturer Approval	Goodyear E85 Ethanol hose .pdf	

Gaskets & Seals Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
NA	NA	Not Applicable		NA

Joint Dopes & Adhesives Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
PIPE DOPE	GASOILA E SEAL	Manufacturer Approval	Gasoil E-Seal.pdf	

Correspondence Contact**Submitter Name** CHRIS DERRO**Job Title** PRESIDENT**Company** Cardinal Compliance LLC**Phone Number** (708) 717-2676**Email** CDERRO@CARDINALCOMPLIANCE.NET**Contractor License #** IL002418☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.