



Blended Fuel Compatibility Form

Facility - 2023209	Tank - 11
Facility Name BP AM-PM	Tank Material Fiberglass Double Wall
Address 700 East Route 45 Mundelein, IL 60060	Tank Capacity 4,000
County Lake	Tank Product E-85
Contact Name Waseem Ahmed	Tank Install Date 12/21/2016
Phone Number	

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	XERXES	Manufacturer Approval		

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Ameron Dualoy 3000/LCX	Manufacturer Approval		

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	Bravo Single wall	Manufacturer Approval		
Single Wall Dispenser	Franklin Fueling/Poly	Manufacturer Approval		

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Hydrostatic Reservoir Interstitial Monitoring Sensors with monitor	Veeder Root/793480-345	Manufacturer Approval		
ATG Probe	Veeder Root/846391-407	Manufacturer Approval		

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder Root/859080-001	Manufacturer Approval		
Non-Discriminating Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Veeder Root/794380-323	Manufacturer Approval		

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	OPW-1C Series	Manufacturer Approval		

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW-71SOM-410C	Manufacturer Approval		

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Gilbarco- Flex Dispenser	Encore- Flex Series	Manufacturer Approval		

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name Ravindra Penmatsa
Job Title Business Director
Company Ampsco Services
Phone Number (312) 286-6722
Email ravi@ampsco.net
Contractor License # IL002420

By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.