



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL

Blended Fuel Compatibility Form

Facility - 4012615

Facility Name Road Ranger #132
Address 4910 N. Market Street
Champaign, IL 61820
County Champaign
Contact Name Jason Martin
Phone Number (815) 540-0688

Tank - 10

Tank Material Composite Double Wall
Tank Capacity 5,000
Tank Product E-85
Tank Install Date 12/8/2010

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Composite Double Wall	Glasteel II	Manufacturer Approval		

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Ameron Dualoy 3000/LCX	Manufacturer Approval		
flex connectors	Franklin Fueling/FLEX-ING	Manufacturer Approval		

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall STP/Tanktop Sump	OPW pisces/ polyethylene	Manufacturer Approval		
UDC	OPW Polyethylene	Manufacturer Approval		

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non Discriminating solid state interstitial sensor	Veeder root	Manufacturer Approval		
ATG Probe	Veeder Root Mag Plus Probes stainless steel	Manufacturer Approval		

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Mechanical Pressurized Line Leak Detection	FE Petro STP MLDS+AG	Manufacturer Approval		
Non-Discriminating Sump Sensor with positive shutdown in Double Wall STP/Tanktop Sump	Veeder Root TLS 450 position sensitive sensor	Manufacturer Approval		

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	OPW 1-2100 series	Manufacturer Approval		

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Ball Float Vent Valve	OPW 53VML	Manufacturer Approval		

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Dispensers	Gilbarco Encore and Encore S	Manufacturer Approval		
STP	FE petro/STPAG	Manufacturer Approval		

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name Todd Johnston
Job Title Project Manager
Company Road Ranger L.L.C.
Phone Number (815) 315-2408
Email tjohnston@roadrangerusa.com

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.