

**Blended Fuel Compatibility Form**

Facility - 2045855

Facility Name Murphy USA #7580
Address 1481 IL Rt 59
Shorewood, IL 60404
County Will
Contact Name Rhonda Roberson
Phone Number (815) 254-3841

Tank - 4

Tank Material Fiberglass Double Wall
Tank Capacity 8,000
Tank Product E85
Tank Install Date 9/3/2015

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	XERXES	Manufacturer Approval	xerxes tanks.pdf	

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Ameron Dualoy 3000/LCX	Manufacturer Approval	NOV LCX pipe and fittings .pdf	

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Dispenser Sump	B8256-D30	Manufacturer Approval	bravo fibeerglass sumps a ll.pdf	
Single Wall STP/Tanktop Sump	Bravo, B427	Manufacturer Approval	bravo fibeerglass sumps a ll.pdf	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
ATG Probe	Veeder Root 846391-507	Manufacturer Approval	veeder root probes.pdf	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Mechanical Pressurized Line Leak Detection	Franklin 403169901	Manufacturer Approval	franklin mllld.pdf	

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	Emco Wheaton Retail, A1004EVR-317SS100	Manufacturer Approval	Emco A1004 & 1005 contain ers.pdf	

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	A1100EVR-057E	Manufacturer Approval	Scan202EMCO E-85 Compatib ility Drop Tube.pdf	Replacing from Permit Application.
Overfill Alarm	Veeder Root	Manufacturer Approval	veeder root probes.pdf	The probe is the only part of the overfill alarm that is in contact with the pro...

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible Pump	Franklin 4020159	Manufacturer Approval	franklin stp.pdf	
Dispenser	Wayne EB23/5220D3	Manufacturer Approval	wayne dispensers all.pdf	

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name Keith Duda

Job Title Project Manager

Company Anderson Pump Service, Inc.

Phone Number (708) 560-5590

Email keith@andersonpump.com

Contractor License # IL002275

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.