



Blended Fuel Compatibility Form

Facility - 2009053

Facility Name 7-Eleven Store #38397
Address 1699 Landmeir Road
 Elk Grove Village, IL 60007
County Cook
Contact Name Sonal Aman
Phone Number (773) 899-6043

Tank - 8

Tank Material Composite Double Wall
Tank Capacity 4,000
Tank Product E-85
Tank Install Date 8/27/2009

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Composite Double Wall	Glasteel II MODERN WELDING	Lab Certification		Page 9 right side Modern Welding

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Ameron Dualoy 3000/LCX	Manufacturer Approval		

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump and dispenser sumps	opw tank sumps	Manufacturer Approval		

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensors	Veeder Root 794380-323	Manufacturer Approval		
ATG Probe	Veeder Root 846391-410	Manufacturer Approval		

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder Root 848480-001	Manufacturer Approval		
Non-Discriminating Sump Sensor in Single Wall STP/Tanktop Sump	Veeder Root 794380-323	Manufacturer Approval		

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	opw Edge	Manufacturer Approval		Page 6

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW 71SOM-412C	Manufacturer Approval		page 6

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Gilbarco	E700 S	Manufacturer Approval		

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name Stephen Kryl
Job Title Project Manager
Company Anderson Pump Service
Phone Number (708) 243-9081
Email steve@andersonpump.com
Contractor License # IL002275

By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.