



Blended Fuel Compatibility Form

Facility - 2021041

Facility Name Citgo Gas & Mini-Mart
Address 3759 West Chicago
 Chicago, IL 60607
County Cook
Contact Name Salim Mohsin
Phone Number (773) 722-6757

Tank - 7

Tank Material Fiberglass Double Wall
Tank Capacity 4,000
Tank Install Date 3/7/2003
Current Product on File Diesel Fuel
Newly Reported Product E85

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Modern Welding	Manufacturer Approval	Glasteel II BioFuels Compatibility 2018.pdf	Existing

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Flexible Double Wall	Total Containment	Manufacturer Approval	flexpip4 EPA OUST Letter Piping Suppliers.pdf	Existing
Shear Valve	OPW 10 Series	Manufacturer Approval	opw e85 shear valve.pdf	New

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	Total Containment	Manufacturer Approval	flexpip4 EPA OUST Letter Piping Suppliers.pdf	Existing
Single Wall UDC Sump	Total Containment	Manufacturer Approval	flexpip4 EPA OUST Letter Piping Suppliers.pdf	Existing

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
ATG Probe	Veeder Root TLS 300 Model #846397-407	Manufacturer Approval	veeder root probes.pdf	New per permit

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Mechanical Pressurized Line Leak Detection	Frankling Mechanical Model #403169901	Manufacturer Approval	franklin mlld.pdf	New per permit
Sump Sensor in Single Wall STP/Tanktop Sump	Veeder Root Model #794380-323	Manufacturer Approval	veeder root sensors all.pdf	New per permit

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	OPW 2100 Series	Manufacturer Approval	Opw spill containers.pdf	Existing

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	Franklin Defender	Manufacturer Approval	FFS-0392 Defender Series OPV Datasheet.pdf	New per permit

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible Turbine Pump	Franklin STP	Manufacturer Approval	franklin stp.pdf	New per permit
Dispenser	Wayne	Manufacturer Approval	wayne dispensers all.pdf	New per permit
Nozzle	OPW 11BP Series	Manufacturer Approval	opw-11bp-series-ethanol-nozzles_2018.pdf	New per permit
Hose	Continental Flexsteel Futura	Manufacturer Approval	Continental_Goodyear_flex steel hoses.pdf	New per permit

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name Ben Olthoff
Job Title Project Manager
Company B&K Equipment
Phone Number (708) 474-3344
Email ben.olthoff@bkequip.com
Contractor License # IL1207

By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.