



### Blended Fuel Compatibility Form

Facility - 5042961

**Facility Name** Qik-n-EZ  
**Address** 103 Comfort Drive  
 South Jacksonville, IL 62651  
**County** Morgan  
**Contact Name** Nicole Menge  
**Phone Number** (217) 243-3400

Tank - 3

**Tank Material** Fiberglass Single Wall  
**Tank Capacity** 8,000  
**Tank Product** E85  
**Tank Install Date** 11/10/2005

#### Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Single Wall	Containment Solutions	Manufacturer Approval	CSI E98 COMPATIBLE UST Containment Solutions-Compatibility B99 & E85.pdf	

#### Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	A.O. Smith	Manufacturer Approval	NOV E98 COMPATIBLE Red Thread IIA Piping Compatible Fuels B99 & E85.pdf	

#### Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	Bravo Sump	Manufacturer Approval	BRAVO Altern. Fuel and Fuel Comp. Statement_PEmped_2024.pdf	
Single Wall UDC Sump	Bravo Sump	Manufacturer Approval	BRAVO Altern. Fuel and Fuel Comp. Statement_PEmped_2024.pdf	

#### Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensors	Franklin Fueling FMP-E1S	Manufacturer Approval	FRANKLIN FUELING E98 COMPATIBILITY - ALL PARTS.pdf	
ATG Probe	Franklin Fueling FMP-LL3-125-1	Manufacturer Approval	FRANKLIN FUELING E98 COMPATIBILITY - ALL PARTS.pdf	

#### Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Franklin Fueling - INC-TS-ELLD	Manufacturer Approval	FRANKLIN FUELING E98 COMPATIBILITY - ALL PARTS.pdf	
Piping Sump Sensors Not Regulated Not Required in Single Wall STP/Tanktop Sump	Franklin Fueling FMP-ULS	Manufacturer Approval	FRANKLIN FUELING E98 COMPATIBILITY - ALL PARTS.pdf	

#### Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	Franklin Fueling - EBW L 705545011CI-GKT	Manufacturer Approval	FRANKLIN FUELING E98 COMP ATIBILITY - ALL PARTS.pdf	

### Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Alarm	Franklin Fueling - INC TS-RA1	Manufacturer Approval	FRANKLIN FUELING E98 COMP ATIBILITY - ALL PARTS.pdf	

### Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible Turbine Pump	Franklin Fueling FEP L 402568924-2HP	Manufacturer Approval	FRANKLIN FUELING E98 COMP ATIBILITY - ALL PARTS.pdf	

### Gaskets & Seals Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Seals / Gaskets	Viton	Manufacturer Approval	Viton - Sanitary butterfly seal.pdf	

### Joint Dopes & Adhesives Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Dope	Gasolia	Manufacturer Approval	Gasolia+-E+seal+E20.pdf	

### Correspondence Contact

<p><b>Submitter Name</b> Anthony Mannino</p> <p><b>Job Title</b> Project Coordinator</p> <p><b>Company</b> Illinois Oil Marketing Equipment, Inc.</p> <p><b>Phone Number</b> (309) 202-0792</p> <p><b>Email</b> amannino@iome.com</p> <p><b>Contractor License #</b> IL1293</p>	<p><input checked="" type="checkbox"/> By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.</p>
---	--