



### Blended Fuel Compatibility Form

Facility - 2045975

**Facility Name** Lenny's Gas N Wash  
Shorewood, LLC

**Address** 1201 W. Jefferson Street  
Shorewood, IL 60404

**County** Will

**Contact Name** Jeff Moberg

**Phone Number** (815) 280-6590

Tank - 3

**Tank Material** Fiberglass Double Wall

**Tank Capacity** 10,000

**Tank Product** E85

**Tank Install Date** 10/7/2015

#### Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	XERXES	Lab Certification	UGPetroleumStorageTankWar r.5.1.2019.pdf	

#### Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Sheer valve	opw	Lab Certification	OPW.pdf	
Flex Connector	Franklin	Lab Certification	Fire flex flexes.pdf	
Fiberglass Double Wall	Ameron Dualoy 3000/LCX	Lab Certification	Ameron Piping.pdf	

#### Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single wall UDC	Bravo	Lab Certification	Bravo_Fittings_Alternativ eFuels_R3.pdf	
STP	Single wall Xerxes STP with Bravo Entry's	Lab Certification	Bravo_Fittings_Alternativ eFuels_R3.pdf	
Single Wall STP/Tanktop Sump	xerxes	Lab Certification	Xerxes Containment Sump U pgrades (1).pdf	

#### Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensors With Monitor	Veeder Root 794380-345	Manufacturer Approval	E85 sensors.pdf	New from Permit Application.
Non-Discriminating Interstitial Monitoring Sensors	Veeder Root 794390-323	Manufacturer Approval	E85 sensors.pdf	

#### Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder Root	Lab Certification	Veeder Root Sensors.pdf	
Non-Discriminating Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Veeder Root	Lab Certification	Veeder Root Sensors.pdf	

#### Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	OPW	Lab Certification	Defender spill bucket.pdf	

#### Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	opw 71som	Lab Certification	OPW.pdf	

**Pump Equipment**

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Gilbarco Dispensers	Gilbarco	Lab Certification	Gilbarco.pdf	
Submersible Pump	opw	Lab Certification	Fe Petro Subs.pdf	
Nozzles and hoses	Catlow	Lab Certification	Catlow.pdf	

**Gaskets & Seals Equipment**

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

**Joint Dopes & Adhesives Equipment**

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

<b>Correspondence Contact</b>		<input checked="" type="checkbox"/> By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.
<b>Submitter Name</b>	Steve Kryl	
<b>Job Title</b>	Project Manager	
<b>Company</b>	Anderson Pump Service, Inc.	
<b>Phone Number</b>	(708) 243-9081	
<b>Email</b>	steve@andersonpump.com	
<b>Contractor License #</b>	IL002275	