



Franklin Fueling Systems

May 4, 2018

Subject: Franklin Fueling Overfill Prevention Valve (OPV) and Spill Prevention Equipment Fuel Compatibility

To Whom It May Concern,

This letter affirms that the materials used by Franklin Fueling Systems in the construction of the Overfill Prevention Valve (OPV) and Spill Prevention Equipment listed herein, as of the date of this letter, is compatible with the following fuels as defined by ASTM;

Group 1

- Gasoline (E0 to E10)
- Diesel (B0 to B5)
- Heating Fuels (Kerosene, Fuel Oil)

Group 2

- Mid-level Ethanol Fuel Blends (E11 to E50)
- Ethanol Fuel Blends (E51 to E83*)

*Commercially known as E85

E Fuel

Group 3

- Biodiesel Blends (B5 to B20) and Biodiesel (B100)

B:O

Group 4

- Aviation Fuels (AvGas, Jet Fuel)

Overfill Prevention Valves

Model Numbers		Groups
708591901, 708591902, 708592901, 708592902, 708593901, 708593902	Defender Series™ OPVs with standard drop tubes	1
708591921, 708591922, 708592921, 708592922, 708593923, 708593924, 708594901, 708594902	Defender Series™ OPVs, AGB	1, 2, 3, 4
708228901	Defender Series™ Remote fill splice kit	1, 2, 3, 4