



Blended Fuel Compatibility Form

Facility - 2035301		Tank - 7	
Facility Name	Woodstock BP (SS# 155)	Tank Material	Tank - Fiberglass Double Wall Containment Solutions
Address	870 East South Street Woodstock, IL 60098	Tank Capacity	10,000
County	McHenry	Tank Product	E-85
Contact Name	Mattie Nelson	Tank Install Date	Not Installed
Phone Number	(815) 337-0699		

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Containment Solutions	Manufacturer Approval	CSI alcohol compatibility statement 9-25-03.pdf	From Permit Application

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Flexible Double Wall	NUPI Smartflex	Manufacturer Approval	NUPI UL LETTER - COMPATIBILITY.pdf	From Permit Application
Other Pump	Submersible	Manufacturer Approval	FE Petro STP Compatibility Statement.pdf	From Permit Application
Shear Valves	OPW 10P Series	Manufacturer Approval	OPW 10 Plus Impact Compatibility.pdf	From Permit Application

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	Containment Solutions SW STP Sump	Manufacturer Approval	CSI Compatibility Statement.pdf	From Permit Application
UDC's	Nupi	Manufacturer Approval	SMFX SUMPS E85 declaration_NA.pdf	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensors With Monitor	Veeder Rootder Root Dry Interstice	Manufacturer Approval	Veeder Root Sensor Compatibility Statement.pdf	From Permit Application
ATG Probe	Veeder Rootder Root Root Alternative Fuels	Manufacturer Approval	Veeder Root E85 probe 577 013-054.pdf	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder Root DPLLD	Manufacturer Approval	Veeder Root PLLD_DPLLD Fuel Compatibility.pdf	From Permit Application
Non-Discriminating Sump Sensor with positive shutdown	Veeder Rootder Root 323	Manufacturer Approval	Veeder Root Sensor Compatibility Statement.pdf	From Permit Application

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	Franklin Defenderklin Defender SW Bucket	Manufacturer Approval	FE PETRO DEFENDER ffs-013 0-defender-series-brochur e-713-web.pdf	From Permit Application

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	Franklin Defender	Manufacturer Approval	Franklin Defender Series OPV Datasheet.pdf	From Permit Application
Overfill Alarm	Veeder Root	Manufacturer Approval	Veeder Root Sensor Compatibility Statement.pdf	From Permit Application

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
STP's	FE Petro AG Series Submersible Pumps	Manufacturer Approval	FE PETRO STPAPM200-VL2 ff s-0412-60-hz-advanced-pro tection-submersible-turbi ne-pumps-datasheet.pdf	

Gaskets & Seals Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fill Adapter	OPW 61 SALP	Manufacturer Approval	OPW FCS Material Compatibility Matrix 2018 revised 072018.pdf	
Vapor Adapter	OPW 61 VSA	Manufacturer Approval	OPW FCS Material Compatibility Matrix 2018 revised 072018.pdf	

Joint Dopes & Adhesives Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Pipe Dope Sealant	Gasoil E Seal	Manufacturer Approval	Gasoil E-Seal.pdf	

Correspondence Contact

<p>Submitter Name Tim Berg</p> <p>Job Title President</p> <p>Company Performance Tank, Inc.</p> <p>Phone Number (847) 612-6551</p> <p>Email tberg@perftank.com</p> <p>Contractor License # IL881</p>	<p><input checked="" type="checkbox"/> By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.</p>
--	--