



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL

Blended Fuel Compatibility Form

Facility - 7013258

Facility Name ROC One Stop #11
Address 531 East Vine Street
Vienna, IL 62995
County Johnson
Contact Name Carl Brasher
Phone Number (618) 268-4722

Tank - 6

Tank Material Composite Double Wall
Tank Capacity 5,000
Tank Install Date 8/11/2010
Current Product on File E-85
Newly Reported Product E-15

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Composite Double Wall	Glasteel II	Manufacturer Approval	Modern E10-E100.p...	

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Flexible Double Wall	A.P.T. Poly Tech P150SC	Lab Certification	APT Poly P.pdf	
Flex Hose	Hose Master FSmm 1.5	Lab Certification	HOSE MASTER FSMM....	
Shear Valve	EBW 662	Lab Certification	EBW 662 SHEAR VAL...	

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	APT	Manufacturer Approval	APT SUMPS.pdf	
Single Wall UDC Sump	APT	Manufacturer Approval	APT SUMPS.pdf	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensors	Veeder Root 794380-430	Manufacturer Approval	VR Int Sensor 430...	
ATG Probe	Veeder Root 846396-1XX	Manufacturer Approval	VR Probe-109.pdf	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder Root 848480-001	Manufacturer Approval	VR PLLD.pdf	
Non-Discriminating Sump Sensor in Single Wall STP/Tanktop Sump	Veeder Root 794380-208	Manufacturer Approval	VR Sump Sensor 20...	

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	OPW 2100 Series	Manufacturer Approval	OPW 2100.pdf	

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW 61SOM	Manufacturer Approval	OPW 61SOM.pdf	

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submerged Pump	FE Petro STPAG75	Manufacturer Approval	FE Petro STP75AG....	
Dispenser	Wayne Ovation B23 with XFLO upgrade	Manufacturer Approval	Wayne XFLO.pdf	
Hoses	Contitech Futura E25	Manufacturer Approval	Contitech E25.pdf	
Breakaway	OPW 66V-0492	Manufacturer Approval	OPW 66V-0492.pdf	
Swivel	OPW 241TPS-0492	Manufacturer Approval	OPW 241TPS-0492.p...	
Nozzle	OPW 11BP	Manufacturer Approval	OPW 11BP.pdf	

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name Adam Laws
Job Title Sales Rep
Company Mid-South Steel
Phone Number (573) 275-3002
Email adam@midsouthsteel.com

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.