



Blended Fuel Compatibility Form

Facility - 2042257

Facility Name Ogden Pulaski BP
Address 3939 Ogden Avenue
 Chicago, IL 60623
County Cook
Contact Name Maneev Abraham
Phone Number (847) 682-3129

Tank - 4

Tank Material Fiberglass Double Wall
Tank Capacity 4,000
Tank Install Date 7/16/2018
Current Product on File B-11
Newly Reported Product E15

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	XERXES	Manufacturer Approval		

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Flexible Double Wall	NUPI Smartflex	Manufacturer Approval		
Shear Valve	OPW	Manufacturer Approval		

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	Bravo	Manufacturer Approval		
Single Wall UDC Sump	Bravo	Manufacturer Approval		

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensors	Veeder Root 794380-345	Manufacturer Approval		
ATG Probe	Veeder Root	Manufacturer Approval		

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Mechanical Pressurized Line Leak Detection	Franklin 403169901	Manufacturer Approval		
Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Veeder root	Manufacturer Approval		

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	OPW	Manufacturer Approval		

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW 71so	Manufacturer Approval		

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible Turbine Pump	Franklin STPAG	Manufacturer Approval		
Nozzle	OPW 11BP-0400	Manufacturer Approval		
Hose	Continental	Manufacturer Approval		

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

<p>Submitter Name Darren White</p> <p>Job Title Project Manager</p> <p>Company B&K Equipment Company</p> <p>Phone Number (708) 474-3344</p> <p>Email DJ.white@BKEQUIP.COM</p> <p>Contractor License # IL1207</p>	<p><input checked="" type="checkbox"/> By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.</p>
--	--