

**Blended Fuel Compatibility Form**

Facility - 2047474

Facility Name Chicago Innovation Group
Address 6700 S Halsted
Chicago, IL 60624
County Cook
Contact Name Mohammed Abdallah
Phone Number (773) 447-2771

Tank - 6

Tank Material Tank - Composite Double
Wall Glasteel II
Tank Capacity 6,000
Tank Product E-85
Tank Install Date 8/25/2022

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Composite Double Wall	Glasteel II	Manufacturer Approval	Glasteel II BioFuels Compatibility 2018.pdf	From Permit Application

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Flexible Double Wall	NUPI Smartflex	Manufacturer Approval	NUPI UL LETTER - COMPATIBILITY.pdf	From Permit Application
Shear Valve	OPW 10 PLUS	Manufacturer Approval	OPW 10 Plus Impact Compatibility.pdf	

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	BRAVO B421	Manufacturer Approval	Bravo Sump Compatibility Statement.pdf	From Permit Application

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensors	VEEDER ROOT 794380-323	Manufacturer Approval	Veeder Root Sensor Compatibility Statement.pdf	From Permit Application
ATG Probe	846391-107	Manufacturer Approval	Veeder Root E85 probe 577 013-054.pdf	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Mechanical Pressurized Line Leak Detection	FE PETRO MLD E	Manufacturer Approval	FE Petro MLD Compatibility.pdf	From Permit Application
Non-Discriminating Sump Sensor with positive shutdown	794380-323	Manufacturer Approval	Veeder Root Sensor Compatibility Statement.pdf	From Permit Application

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	OPW 1-3100 EDGE	Manufacturer Approval	OPW Belowground Product Compatibility Listing 0715 18.pdf	From Permit Application

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW 71SOM	Manufacturer Approval	OPW 71SOM_Overfill_Prevention_Valve.pdf	From Permit Application

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
NA	NA	Not Applicable		DISPENSERS ONLY LISTED
Submersible Turbine Pump	FE PETRO STP AG	Manufacturer Approval	FE Petro STP Compatibility Statement.pdf	
Suction Pump	NA	Not Applicable		NO SUCTION PUMP WILL BE USED.
Dispenser	WAYNE OVATION	Manufacturer Approval	WAYNE MH1821-45-6 Ovation Certificate of Compliance. pdf	
Nozzle	OPW 11A	Manufacturer Approval	OPW 11a-and-11b-automatic -nozzles.pdf	
Hose	FLEXING	Manufacturer Approval	Flexing Compatibility Statement.pdf	

Gaskets & Seals Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
NA	NA	Not Applicable		GASKETS AND SEAL ARE PART OF UNITS. NOT LISTED SEPARATELY.

Joint Dopes & Adhesives Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
PIPE DOPE	GASOILA E SEAL	Manufacturer Approval	Gasola E-Seal.pdf	

Correspondence Contact

Submitter Name CHRIS DERRO

Job Title PRESIDENT

Company Cardinal Compliance LLC

Phone Number (708) 717-2676

Email CDERRO@CARDINALCOMPLIANCE.NET

Contractor License # IL002418

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.