



Blended Fuel Compatibility Form

Facility - 2046249

Facility Name	Thorntons #322
Address	3450 S. California Avenue Chicago, IL 60608
County	Cook
Contact Name	Scott Roberts
Phone Number	(502) 425-8022

Tank - 6

Tank Material	Fiberglass Brine Filled Double Wall
Tank Capacity	6,000
Tank Product	E85
Tank Install Date	9/29/2016

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Brine Filled Double Wall	Containment Solutions	Manufacturer Approval	Containment Solutions Tanks and Sumps.pdf	

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Ameron Dualoy 3000/LCX	Manufacturer Approval	Ameron Piping.pdf	

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Dispenser Sump	Bravo B-1000-OV	Manufacturer Approval	Bravo Dispenser Sump.pdf	
Single Wall STP/Tanktop Sump	Containment Solutions	Manufacturer Approval	Containment Solutions Tanks and Sumps.pdf	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
ATG Probe	Veeder Root 846391-410	Manufacturer Approval	Veeder Root Probe & Float .pdf	
Non-Discriminating Interstitial Monitoring Sensors	Veeder Root 794380-303	Manufacturer Approval	Veeder Root Sump & Interstitial Sensors.pdf	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder Root DPLLD	Manufacturer Approval	Veeder Root Electronic Leak Detector.pdf	
Non-Discriminating Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Veeder Root 794380-323	Manufacturer Approval	Veeder Root Sump & Interstitial Sensors.pdf	

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	Defender	Manufacturer Approval	8+Spill+Bucket.pdf	

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	Franklin	Manufacturer Approval	Franklin+Defender+Overfill.pdf	

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible Turbine Pump	Franklin Fueling ISTMVS4-VL2	Manufacturer Approval	FE Petro Submersible Pump .pdf	

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name Amber Pena
Job Title Director of Service
Company Stenstrom Petroleum Services Group
Phone Number (815) 398-6250
Email amberp@rstenstrom.com
Contractor License # IL1890

By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.