

**OFFICE OF THE ILLINOIS STATE FIRE MARSHAL****Blended Fuel Compatibility Form****Facility - New**

Facility Name	Lenny's Gas N Wash Orchard and Jericho, LLC.
Address	1055 Orchard Road Montgomery, IL 60538
County	Kane
Contact Name	Lenny McEnery
Phone Number	(708) 444-0117

Tank - 5

Tank Material	Tank - Fiberglass Double Wall XERXES
Tank Capacity	10,000
Tank Product	E-85
Tank Install Date	Not Installed

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Tank - Fiberglass Double Wall XERXES	XERXES Fiberglass	Lab Certification	e85 xerxes.pdf	From Permit Application

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Piping - Fiberglass Double Wall Ameron Dualoy 3000/LCX	Ameron Fiberglass Dualoy 3000/LCX	Lab Certification	e85 frp pipe.pdf	From Permit Application
Piping - Flex Connector Steel	Franklin Fueling	Lab Certification	e85 franklin all....	From Permit Application
Piping - Other Steel Riser	Steel	Not Applicable		From Permit Application
Piping - Other Submersible Pump	Submersible	Lab Certification	e85 franklin all....	From Permit Application
Piping - Ball Valves	Franklin	Lab Certification	e85 franklin all....	From Permit Application
Piping - Shear Valves	OPW 10 P	Lab Certification	e85 opw.pdf	From Permit Application

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Piping - Single Wall STP/Tanktop Sump	Bravo	Lab Certification	e85 bravo.pdf	From Permit Application

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Leak Detect - Tank - Non-Discriminating Interstitial Monitoring Sensors	Veeder Root 794380-345	Lab Certification	e85 veeder sensor...	From Permit Application
ATG Probe	Veeder Root 846391-410	Lab Certification	e85 veeder probe....	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Leak Detect - Piping - Electronic Pressurized Line Leak Detection	Veeder Root 848480-001	Lab Certification	e85 veeder PLLD.p...	From Permit

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Application Comment
Leak Detect - Piping - Non-Discriminating Sump Sensor with positive shutdown	Veeder Root 794380-323	Lab Certification	e85 veeder sensor...	From Permit Application

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Spill Contain Device - Double Wall Spill Bucket	FE Petro Defender 705555112CI-GKT	Lab Certification	e85 franklin spil...	From Permit Application

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Prev Device - Overfill Alarm	veeder root	Not Applicable		From Permit Application
Overfill Prev Device - Overfill Drop Tube Valve	opw 71SOM	Lab Certification	e85 opw.pdf	From Permit Application

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Gilbarco	E700 S	Lab Certification	e85 gilbarco.pdf	

Gaskets & Seals Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
gaskets and seals	None	Not Applicable		None being used that are not part of an approved assembly

Joint Dopes & Adhesives Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Gasoil E Seal	Gasoil E Seal	Lab Certification	e85 dope.pdf	

Correspondence Contact

Submitter Name Stephen Kryl
Job Title Project Manager
Company Stephen Kryl
Phone Number (708) 243-9081
Email steve@andersonpump.com
Contractor License # IL002275

By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.