



### Blended Fuel Compatibility Form

<b>Facility - 4039861</b>		<b>Tank - 1</b>	
<b>Facility Name</b>	Heritage FS Fuel 24	<b>Tank Material</b>	Fiberglass Single Wall
<b>Address</b>	395 West 1st Route 9 & Route 54 Gibson City, IL 60936	<b>Tank Capacity</b>	12,000
<b>County</b>	Ford	<b>Tank Product</b>	E-85
<b>Contact Name</b>	Jason Main	<b>Tank Install Date</b>	10/17/2000
<b>Phone Number</b>	(217) 784-4259		

#### Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Single Wall	Containment Solutions	Manufacturer Approval		Tank Install date: 10/2000

#### Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Flexible Double Wall	A.P.T. Poly Tech P-175-SC	Manufacturer Approval		
Shear Valves	EBW 662 E-Coated	Manufacturer Approval		

#### Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	APT TSM 3647	Manufacturer Approval		
Dispenser UDC's	APT LMM 2915	Manufacturer Approval		UDC's 1,2 - 3,4

#### Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
ATG Probe	Veeder Root 846391-107	Manufacturer Approval		

#### Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Mechanical Pressurized Line Leak Detection	Red Jacket FX1V	Manufacturer Approval		
Non-Discriminating Sump Sensor in Single Wall STP/Tanktop Sump	Veeder Root 794380-323	Manufacturer Approval		
Non-Discriminating Sump Sensor in Single Wall UDC	Veeder Root 794380-323	Manufacturer Approval		UDC's 1,2 - 3,4

#### Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	EBW 705 GL with DPM Liner Kit	Manufacturer Approval		

### Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Alarm	Veeder Root 790091-001 Alarm, 790095-001 ACK switch	Manufacturer Approval		Does NOT come into contact with E85
Over Fill Drop Tube	FF Defender 708691922 AGB	Manufacturer Approval		

### Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fuel Dispensers	Gilbarco NL1 Flex Fuel	Lab Certification		
Submerged Turbine Pump	FePetro STPAG150-VL2	Manufacturer Approval		
Dispensing Nozzles	OPW 21 GE-0992	Manufacturer Approval		
Hose Swivels	OPW 241TPS-0492	Manufacturer Approval		
Break A Ways	OPW 66V-0492	Manufacturer Approval		
Dispensing Hoses (Curb and Whip)	VST V34FF-096-MRMR, V34FF-009-MRMR	Manufacturer Approval		

### Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

### Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

#### Correspondence Contact

**Submitter Name** Butch VonDrehle  
**Job Title** Owner  
**Company** Pemco Service Co.,Inc.  
**Phone Number** (815) 265-7364  
**Email** pemcogilman@sbcglobal.net  
**Contractor License #** IL1224

By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.