



### Blended Fuel Compatibility Form

Facility - 1045429

<b>Facility Name</b>	Love's Travel Stop #529
<b>Address</b>	1001 W. Walnut Street Oglesby, IL 61348
<b>County</b>	LaSalle
<b>Contact Name</b>	Monica Snell
<b>Phone Number</b>	(815) 883-3561

Tank - 7

<b>Tank Material</b>	Fiberglass Double Wall
<b>Tank Capacity</b>	20,000
<b>Tank Product</b>	B-99
<b>Tank Install Date</b>	8/20/2013

#### Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Containment Solutions	Manufacturer Approval	Containment Solutions-Compatibility B99 & E85.pdf	

#### Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Ameron Fiberglass Dualoy 3000/LCX	Manufacturer Approval	Dualoy+3000+LCX+Data+Sheet B99 & E85.pdf	From Permit Application
Fiberglass Double Wall	Ameron Dualoy 3000/LCX	Manufacturer Approval	Dualoy+3000+LCX+Data+Sheet B99 & E85.pdf	

#### Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
UDC	Bravo	Manufacturer Approval	Bravo_Sumps_AlternativeFuels_R3 B99 & E85.pdf	
Single Wall STP/Tanktop Sump	Bravo	Manufacturer Approval	Bravo_Sumps_AlternativeFuels_R3 B99 & E85.pdf	

#### Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
ATG Probe	Veeder Root	Manufacturer Approval	!!!!Veeder-Root - Fuel Compatibility Letter - Executed - 2015-09-23 (2).pdf	
Non-Discriminating Interstitial Monitoring Sensors	Veeder Root 07944380-345	Manufacturer Approval	V-R_794380-345_Intersitia lSensor.pdf	

#### Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder Root	Manufacturer Approval	V-R_848480-003_PLLD.pdf	
Non-Discriminating Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Veeder Root 0794380-321	Manufacturer Approval	V-R_794380-321_SumpSensor .pdf	

#### Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	OPW	Manufacturer Approval	opw-fuel-compatibility-be low-ground-products-2018. pdf	

#### Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Alarm	Veeder Root	Manufacturer Approval	576047-241_Overfill_Alarm .pdf	
Overfill Drop Tube Valve	Franklin Fueling	Manufacturer Approval	FFS-0392 Defender Series OPV Datasheet B99.pdf	

### Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
STP	Veeder Root	Manufacturer Approval	!!!Veeder-Root - Fuel Compatibility Letter - Executed - 2015-09-23 (2).pdf	

### Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

### Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

### Correspondence Contact

<b>Submitter Name</b>	Anthony Marketing	<input checked="" type="checkbox"/> By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.
<b>Job Title</b>	project manager	
<b>Company</b>	Illinois Oil Marketing Equipment, Inc.	
<b>Phone Number</b>	(309) 202-0792	
<b>Email</b>	amannino@iome.com	
<b>Contractor License #</b>	IL1293	