

**Blended Fuel Compatibility Form**

Facility - 2008992

Facility Name I-57 Fuel Mart (Gulf)
Address 9901 S. Halsted
Chicago, IL 60628
County Cook
Contact Name Khalil Abdullah
Phone Number (708) 259-4539

Tank - 9

Tank Material Fiberglass Single Wall
Tank Capacity 10,000
Tank Product E85
Tank Install Date 1/1/1986

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Single Wall	NOV	Manufacturer Approval		

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Ameron Dualoy 3000/LCX	Manufacturer Approval		
Shear Valve	OPW, 10P-0152E85	Manufacturer Approval		

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	Franklin fueling/TSM 4542	Manufacturer Approval		
Single Wall UDC Sump	franklin fueling/APT poly	Manufacturer Approval		

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
ATG Probe	Veeder Root/ Mag plus probe for alternate fuels	Manufacturer Approval		

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Mechanical Pressurized Line Leak Detection	Fe-petro/MLD	Manufacturer Approval		
Sump Sensor in Single Wall STP/Tanktop Sump	Veeder Root/Veeder-Root 794380-323 position sensitive Sump Sensor	Manufacturer Approval		

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	OPW/OPW 2100C	Manufacturer Approval		

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	EMCO/A1100 ("E" variant) A1100EVR ("E" variant)	Manufacturer Approval		

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible Turbine Pump	Franklin 4020159	Manufacturer Approval		
Dispenser	Gilbarco® Encore® 700 S or S dispensers	Manufacturer Approval		
Nozzle	OPW, 11BP-0992-E85	Manufacturer Approval		
Hose	VST	Manufacturer Approval		

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact		☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.
Submitter Name	Haibat KHAN	
Job Title	manager	
Company	American Petroleum Solutions	
Phone Number	(909) 312-9449	
Email	apetro.office@gmail.com	