

**Blended Fuel Compatibility Form**

Facility - 3021275

Facility Name Ag Land FS, Inc.
Address 14104 Baer Road
Tremont, IL 61568
County Tazewell
Contact Name Kyle Deppert
Phone Number (309) 925-5582

Tank - 4

Tank Material Fiberglass Single Wall
Tank Capacity 30,000
Tank Product B-99
Tank Install Date 5/31/2007

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Single Wall	Containment Solutions	Manufacturer Approval	TREMONT CSI.pdf	

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Ameron	Manufacturer Approval	Dualoy+3000+LCX+Data+Sheet B99 & E85.pdf	

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	CSI	Manufacturer Approval	TREMONT CSI.pdf	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
TLS350	VEEDER ROOT	Manufacturer Approval	TREMONT RELEASE DETECTION .pdf	
ATG Probe	VEEDER ROOT/846396	Manufacturer Approval	TREMONT RELEASE DETECTION .pdf	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	VEEDER ROOT/TLS350	Manufacturer Approval	TREMONT RELEASE DETECTION .pdf	
Non-Discriminating Sump Sensor in Single Wall STP/Tanktop Sump	VEEDER ROOT/OPW	Manufacturer Approval	TREMONT RELEASE DETECTION .pdf	

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	OPW/#1	Manufacturer Approval	TREMONT SPILL CONTAINER.p df	

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Alarm	Overfill Alarm Horn	Not Applicable		This horn doesnt touch fuel, The horn is bad the light flashes and activates thr...

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
THE RED JACKET ALCOHOL GAS (AG) STP	THE RED JACKET ALCOHOL GAS (AG) STP	Manufacturer Approval	TREMONT STP.pdf	

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name Anthony Mannino
Job Title Project Coordinator
Company Illinois Oil Marketing Equipment, Inc.
Phone Number (309) 202-0792
Email amannino@iome.com
Contractor License # IL1293

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.