



**Blended Fuel Compatibility Form**

Facility - 2046359

**Facility Name** Murphy USA #8817  
**Address** 2094 N. Illinois Route 50  
 Bradley, IL 60914  
**County** Kankakee  
**Contact Name** Tracy Bladdek  
**Phone Number** (815) 932-3659

Tank - 3

**Tank Material** Fiberglass Double Wall  
**Tank Capacity** 8,000  
**Tank Product** E-85  
**Tank Install Date** 4/13/2017

**Tank Equipment**

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	XERXES	Manufacturer Approval		

**Piping Equipment**

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Ameron Dualoy 3000/LCX	Manufacturer Approval		

**Containment Sump Equipment**

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	Bravo, B427	Manufacturer Approval		
Single Wall Dispenser Sump	Bravo, B8256-D30	Manufacturer Approval		

**Release Detection Tank Equipment**

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensors	Veeder Root, 794380-345	Manufacturer Approval		
ATG Probe	Veeder Root 846391-507	Manufacturer Approval		

**Release Detection Piping Equipment**

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Mechanical Pressurized Line Leak Detection	Franklin 403169901	Manufacturer Approval		
Non-Discriminating Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Veeder Root 794380-323	Manufacturer Approval		

**Spill Prevention Equipment**

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	Emco Wheaton Retail, A1004EVR-317SS100	Manufacturer Approval		

**Overfill Prevention Equipment**

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	EMCO A1100	Manufacturer Approval		

### Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible Pump	Franklin 4020159	Manufacturer Approval		
Dispenser	Wayne EB23/5220D3	Manufacturer Approval		

### Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

### Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

### Correspondence Contact

<b>Submitter Name</b>	Ed Angell	<input checked="" type="checkbox"/> By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.
<b>Job Title</b>	Project Manager	
<b>Company</b>	B&K Equipment Company	
<b>Phone Number</b>	(170) 847-4334	
<b>Email</b>	ed@bkequip.com	
<b>Contractor License #</b>	IL1207	