



Blended Fuel Compatibility Form

Facility - 3031219		Tank - 5	
Facility Name	Ag View FS, Inc.	Tank Material	Fiberglass Single Wall
Address	2194 State Rt. 17 Varna, IL 61375	Tank Capacity	12,000
County	Marshall	Tank Product	B-99
Contact Name	Brad Condit	Tank Install Date	8/25/1992
Phone Number	(309) 463-2400		

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Single Wall	Owens Corning	Manufacturer Approval		Tank was relined by Armor Shield - Clayton Bennett. Attachment is from Clayton o...

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible - STP	FE Petro - ISTAPMVS4-VL2	Manufacturer Approval		From Permit Application - Veeder Root owns Red Jacket and PDF show STP compatibi...
Ball Valves	Morrison Bros - 691BSS08001V	Manufacturer Approval		From Permit Application
Fiberglass Double Wall	Ameron - 3000/L	Manufacturer Approval		

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	Bravo - B422-48-S-01	Manufacturer Approval		From Permit Application

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
ATG Probe	Veeder Root - 846391	Manufacturer Approval		

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Mechanical Pressurized Line Leak Detection	Vaporless _ 99LD-2000 with LD2-SSVS vent kit	Manufacturer Approval		
Non-Discriminating Sump Sensor in Single Wall STP/Tanktop Sump	Veeder Root - 794380-351	Manufacturer Approval		

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	OPW - 1-2100	Manufacturer Approval		

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Alarm	Veeder Root - 846391 Veeder Root - 790095-001 & 790091-001	Manufacturer Approval		The only portion of the overfill alarm that has contact with B-99 is the probe (...)

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible Pump	Franklin FE Petro - ISTAPMVS4-VL2	Manufacturer Approval		The dispensing system is a bulk loading system that is all aboveground. The bulk...

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name Patrick O'Brien
Job Title Sales Manager
Company Howard Lee and Sons, Inc.
Phone Number (815) 298-3767
Email patricko@hleesons.com
Contractor License # IL456

By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.