

**Blended Fuel Compatibility Form**

Facility - 2044569

Facility Name Thornton Oil #307
Address 110 West Devon Ave.
Wood Dale, IL 60191
County Du Page
Contact Name Gus Zuleta
Phone Number (630) 616-0993

Tank - 4

Tank Material Fiberglass Brine Filled Double Wall
Tank Capacity 6,000
Tank Product E-85
Tank Install Date 8/12/2010

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Brine Filled Double Wall	XERXES	Manufacturer Approval		

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Flexible Double Wall	A.P.T. Poly Tech P250SC	Manufacturer Approval		
Chase Secondary Containment	A.P.T. Poly Tech DCT-400	Manufacturer Approval		

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	XERXES	Manufacturer Approval		
UDC	Containment Solutions	Manufacturer Approval		

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Hydrostatic Reservoir Interstitial Monitoring Sensors	Veeder Root TLS-450 Plus	Manufacturer Approval		
ATG Probe	Veeder Root TLS-450 Plus	Manufacturer Approval		

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder Root TLS-450 Plus	Manufacturer Approval		
Non-Discriminating Sump Sensor in Single Wall STP/Tanktop Sump	Veeder Root TLS-450 Plus	Manufacturer Approval		

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	EBW	Manufacturer Approval		

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW 71SOM-412C	Manufacturer Approval		

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
STP	PMAG-VS4 FE Petro	Manufacturer Approval		

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name Jeff Buscemi

Job Title Service Tech

Company Beacon SSI

Phone Number (708) 263-5441

Email Jeff.Buscemi@beaconssi.com

Contractor License # IL002336

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.