

**Blended Fuel Compatibility Form**

Facility - 2046166

Facility Name Thornton's, Inc. Store #318
Address 1330 S Neltor Blvd.
West Chicago, IL 60185
County Du Page
Contact Name Scott Roberts
Phone Number (800) 928-8022

Tank - 3

Tank Material Fiberglass Brine Filled Double Wall
Tank Capacity 6,000
Tank Product E85
Tank Install Date 9/2/2016

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Brine Filled Double Wall	Containment Solutions Double Wall with Brine	Manufacturer Approval	2 +Tank+Sumps+CSI.pdf	

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Ameron Dualoy 3000/LCX	Manufacturer Approval	3+Piping.pdf	

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Dispenser Sump	Bravo	Manufacturer Approval	4+UDC+Bravo.pdf	
Single Wall STP/Tanktop Sump	Containment Solutions SW Fiberglass Tank Sumps	Manufacturer Approval	2 +Tank+Sumps+CSI.pdf	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
ATG Probe	Veeder Root 846391-410	Manufacturer Approval	5+Probe+Float.pdf	
Required Other Monitor only for sensors	Veeder Root TLS 450 Plus	Manufacturer Approval	Veeder Root Compatibility Letter.pdf	New from Permit Application.
Hydrostatic Reservoir Interstitial Monitoring Sensors with monitor	Veeder Root	Manufacturer Approval	Veeder Root Sump & Interstitial Sensors.pdf	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	VR	Manufacturer Approval	VR+PLLD+Fuel+Compatibility.pdf	
Non-Discriminating Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Veeder Root 794380-323	Manufacturer Approval	6+Sensors+VR323+VR303.pdf	

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	Franklin	Manufacturer Approval	8+Spill+Bucket.pdf	

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW 71SOM-412C	Manufacturer Approval	9+Overfill+Prevention+Valve+OPW.pdf	

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Pump	Franklin Fueling IST	Manufacturer Approval	10+Pump+Franklin.pdf	

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name Amber Pena

Job Title Director of Service

Company Stenstrom Petroleum Services Group

Phone Number (815) 398-6250

Email amberp@rstenstrom.com

Contractor License # IL1890

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.