



Blended Fuel Compatibility Form

Facility - 2047411		Tank - 6	
Facility Name	QuikTrip #7208	Tank Material	N/A
Address	1040 S. 25th Ave Bellwood, IL 60104	Tank Capacity	18,000
County	Cook	Tank Product	B-99
Contact Name	Kyla Rudd	Tank Install Date	Unknown
Phone Number	(918) 655-7700		

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Brine Filled Double Wall	XERXES Fiberglass	Manufacturer Approval	Xerxes Tanks and ...	From Permit Application

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Flexible Double Wall	Franklin Fueling Systems UPP	Manufacturer Approval	FFS-0164 UPP Semi...	From Permit Application
Flex Connector Steel	Flex-ing	Manufacturer Approval	Flexible Connecto...	From Permit Application
Shear Valves	OPW	Manufacturer Approval	opw-10-plus-serie...	From Permit Application

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Blending Sump	Bravo B-1000	Manufacturer Approval	Bravo_Sumps_Alter...	From Permit Application
Single Wall STP/Tanktop Sump	PCI	Manufacturer Approval	PCI-BioDiesel.pdf	From Permit Application
Single Wall Transition Sump	PCI	Manufacturer Approval	PCI-BioDiesel.pdf	From Permit Application
Single Wall Dispenser Sump	Bravo B-1000	Manufacturer Approval	Bravo_Sumps_Alter...	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Hydrostatic Reservoir Interstitial Monitoring Sensors with monitor	Veeder Root 794380-304	Manufacturer Approval	Veeder Root Sump ...	From Permit Application
ATG Probe	846391	Manufacturer Approval	Veeder Root Probe...	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder Root DPLLD	Manufacturer Approval	PLLD VR859080-001...	From Permit Application
Non-Discriminating Sump Sensor with positive shutdown	Veeder Root 794380-321	Manufacturer Approval	794380-321.pdf	From Permit Application

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	OPW 1-3100 Series (Edge)	Manufacturer Approval	OPW Compatibility...	From Permit Application

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	Franklin 708592922	Manufacturer Approval	708592922 Overfil...	From Permit Application
Overfill Alarm	Veeder Root	Manufacturer Approval	Veeder Root Probe...	From Permit Application

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible Turbine Pump	FE Petro STPAP	Manufacturer Approval	FFS-0796 Submersi...	

Gaskets & Seals Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Gaskets	Total Control Systems	Manufacturer Approval	682-15-engineerin...	

Joint Dopes & Adhesives Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Pipe Dope	Gasolia	Manufacturer Approval	Gasolia.pdf	

Correspondence Contact

Submitter Name Nick Bugajsky Job Title Project Manager Company Stenstrom Petroleum Services Group Phone Number (708) 485-4105 Email nickb@rstenstrom.com Contractor License # IL1890	<input checked="" type="checkbox"/> By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.
---	---