

**Blended Fuel Compatibility Form**

Facility - 2020427

Facility Name HPG Holding, Inc.
Address 674 N. Broadway
Aurora, IL 60506
County Kane
Contact Name Zhadar Zahdan
Phone Number (708) 372-7632

Tank - 9

Tank Material Composite Double Wall
Tank Capacity 3,000
Tank Product E85
Tank Install Date 10/23/2018

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Composite Double Wall	Glasteel II	Lab Certification		

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Ameron Dualoy 3000/LCX	Manufacturer Approval		
Shear Valve	opw 10p	Manufacturer Approval		

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	Bravo	Manufacturer Approval		
Single Wall UDC Sump	Bravo	Manufacturer Approval		

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensors	Veeder Root 794390-430	Manufacturer Approval		
ATG Probe	Veeder Root 846391-410	Manufacturer Approval		

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder Root 848480-001	Manufacturer Approval		
Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Veeder Root 794380-323	Manufacturer Approval		

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	FE Petro Defender 705555112CI-GKT	Manufacturer Approval		

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW 71SOM-412C	Manufacturer Approval		

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Wayne	Ovation II	Manufacturer Approval		
Submersible Turbine Pump	fe petro	Manufacturer Approval		
Nozzle	opw 21gu-0992-e85	Manufacturer Approval		
Hose	Continental Hose 53233712412169	Manufacturer Approval		

Gaskets & Seals Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
None that are not part of an approved device	None that are not part of an approved device.	Not Applicable		None used that are of part of an approved device.

Joint Dopes & Adhesives Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Gasola E Seal	Gasola E Seal	Manufacturer Approval		

Correspondence Contact

Submitter Name Stephen Kryl
Job Title Project Manager
Company Anderson Pump Service
Phone Number (708) 243-9081
Email steve@andersonpump.com
Contractor License # IL002275

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.