



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL

Blended Fuel Compatibility Form

Facility - 2045118

Facility Name GoLo
Address 4005 W. 135th St.
Robbins, IL 60472
County Cook
Contact Name Mohamed Husain
Phone Number (708) 389-0044

Tank - 2

Tank Material Fiberglass Double Wall
Tank Capacity 7,000
Tank Install Date 6/25/2012
Current Product on File Diesel Fuel
Newly Reported Product E-85

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	XERXES	Manufacturer Approval	xerxes tanks.pdf	

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Flexible Double Wall	A.P.T. Poly Tech P150SC	Manufacturer Approval	Franklin FFS-0524...	

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	Franklin LMD	Manufacturer Approval	franklin poly sum...	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Hydrostatic Reservoir Interstitial Monitoring Sensors	Veeder Root 794380-303	Manufacturer Approval	veeder root senso...	
ATG Probe	Veeder Root 846397-407	Manufacturer Approval	veeder root probe...	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Mechanical Pressurized Line Leak Detection	FE Petro 403169901	Manufacturer Approval	franklin mllld.pdf	
Discriminating Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Veeder Root 794380-323	Manufacturer Approval	veeder root senso...	

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	OPW	Manufacturer Approval	Opw spill contain...	

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW 71SOM-412C	Manufacturer Approval	71SO_Overfill_Pre...	

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
--------------------	--------------------	----------------------	---------------	---------

Compatibility Item	Model/Manufacturer	Method Compatibility Method	Documentation	Comment
Submersible Turbine Pump	Franklin STP 1/3 HP	Manufacturer Approval	franklin stp.pdf	

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name Darren White
Job Title Project Manager
Company B&K Equipment
Phone Number (708) 821-5014
Email dj.white@bkequip.com
Contractor License # IL1207

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.