



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL

Blended Fuel Compatibility Form

Facility - 2022796

Facility Name Pride of Cicero
Address 3100 S. Cicero Avenue
Cicero, IL 60650
County Cook
Contact Name Juan Guzman
Phone Number (630) 653-1700

Tank - 15

Tank Material Fiberglass Double Wall
Tank Capacity 6,000
Tank Product E-85
Tank Install Date 11/9/2012

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	XERXES	Lab Certification		

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Ameron Dualoy 3000/LCX	Lab Certification		

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	Xerxes	Lab Certification		
UDC	Single wall Bravo	Lab Certification		

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
ATG Probe	Veeder Root 846397-409	Lab Certification		
Non-Discriminating interstitial Monitoring Sensor	Veeder Root 794380-430	Lab Certification		

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder Root 859080-001	Lab Certification		
Non-Discriminating Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Veeder Root 794380-323	Lab Certification		

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	opw 1 - 2100	Lab Certification		

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW 71SOM-412C	Lab Certification		

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Wayne	Ovation	Lab Certification		

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name Hoyt Ary
Job Title Project Manager
Company Anderson Pump service
Phone Number (708) 906-6178
Email hoyt@andersonpump.com
Contractor License # IL002275

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.