



Blended Fuel Compatibility Form

Facility - 2021096		Tank - 3	
Facility Name	Fullerton Food & Fuel, Inc. c/o Shell	Tank Material	Fiberglass Single Wall
Address	3959 W. Fullerton Chicago, IL 60647	Tank Capacity	8,000
County	Cook	Tank Install Date	Unknown
Contact Name	Haney Khalil	Current Product on File	Gasoline - Regular
Phone Number	(708) 257-1201	Newly Reported Product	E-85

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Single Wall	Bridgeport lining	Manufacturer Approval	bridgeport tank lining.pdf	

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Flexible Double Wall	NUPI Smartflex	Manufacturer Approval	Nupi-America.pdf	
Flexible Double Wall	Franklin Fueling APT	Manufacturer Approval	franklin apt pipe.pdf	

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	OPW, Pisces series	Manufacturer Approval	opw-fuel-compatibility-matrix-below-ground-products-2018.pdf	
Single Wall Dispenser Sump	OPW, Pisces series	Manufacturer Approval	opw-fuel-compatibility-matrix-below-ground-products-2018.pdf	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Veeder Root TLS 350	Veeder Root, 846391-407	Manufacturer Approval	veeder root probe floats.pdf	
ATG Probe	Veeder Root, 846391-407	Manufacturer Approval	veeder root probe floats.pdf	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder Root 848480-001	Manufacturer Approval	Veeder-Root PLLD.pdf	
Non-Discriminating Sump Sensor in Single Wall STP/Tanktop Sump	Veeder Root 794380-323	Manufacturer Approval	veeder root sensors all.pdf	

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	OPW 1-2100EVR	Manufacturer Approval	Opw spill containers.pdf	

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW 71SOM-412C	Manufacturer Approval	71SOM_Overfill_Prevention_Valve.pdf	

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible Pump	Franklin 4020159	Manufacturer Approval	franklin stp.pdf	
Dispenser	Wayne EB23/5220D3	Manufacturer Approval	wayne dispensers all.pdf	

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name	Ed Angell	<input checked="" type="checkbox"/> By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.
Job Title	Project Manager	
Company	B&K Equipment Company	
Phone Number	(708) 474-3344	
Email	ed@bkequip.com	
Contractor License #	IL1207	