



Blended Fuel Compatibility Form

Facility - 2045303

Facility Name Crete I, LLC
Address 23802 Volbrecht Rd.
 Crete, IL 60417
County Will
Contact Name Alex Singh
Phone Number (219) 775-0313

Tank - 4

Tank Material Fiberglass Double Wall
Tank Capacity 7,000
Tank Product E-85
Tank Install Date 5/7/2013

Tank Equipment

| Compatibility Item | Model/Manufacturer | Compatibility Method | Documentation | Comment |
|------------------------|--------------------|-----------------------|------------------|---------|
| Fiberglass Double Wall | XERXES | Manufacturer Approval | xerxes tanks.pdf | |

Piping Equipment

| Compatibility Item | Model/Manufacturer | Compatibility Method | Documentation | Comment |
|------------------------|------------------------|-----------------------|--------------------------------|-------------------------|
| Other Riser | Steel | Manufacturer Approval | Graco_ChemCompGuideEN-B.p df | From Permit Application |
| Fiberglass Double Wall | Ameron Dualoy 3000/LCX | Manufacturer Approval | NOV LCX pipe and fittings .pdf | |

Containment Sump Equipment

| Compatibility Item | Model/Manufacturer | Compatibility Method | Documentation | Comment |
|------------------------------|----------------------|-----------------------|---|---------|
| Single wall dispenser sump | Franklin APT LM Poly | Manufacturer Approval | APT Sumps E85 Compatibility Letter 08.07.19.pdf | |
| Single Wall STP/Tanktop Sump | Bravo | Manufacturer Approval | bravo fibeerglass sumps a ll.pdf | |

Release Detection Tank Equipment

| Compatibility Item | Model/Manufacturer | Compatibility Method | Documentation | Comment |
|--|------------------------|-----------------------|------------------------------|---------|
| ATG Probe | Veeder root 846391-307 | Manufacturer Approval | Veeder-Root tank probe.pd f | |
| Non-Discriminating Interstitial Monitoring Sensors | Veeder Root 794380-345 | Manufacturer Approval | veeder root sensors all.p df | |

Release Detection Piping Equipment

| Compatibility Item | Model/Manufacturer | Compatibility Method | Documentation | Comment |
|---|------------------------|-----------------------|------------------------------|---------|
| Mechanical Pressurized Line Leak Detection | VMI Vaporless #2000 | Manufacturer Approval | vaporless mfg MLLD.pdf | |
| Non-Discriminating Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump | Veeder Root 794380-323 | Manufacturer Approval | veeder root sensors all.p df | |

Spill Prevention Equipment

| Compatibility Item | Model/Manufacturer | Compatibility Method | Documentation | Comment |
|--------------------------|--------------------|-----------------------|--------------------------|---------|
| Single Wall Spill Bucket | OPW 1C-2100-DEVR | Manufacturer Approval | Opw spill containers.pdf | |

Overfill Prevention Equipment

| Compatibility Item | Model/Manufacturer | Compatibility Method | Documentation | Comment |
|--------------------------|--------------------|-----------------------|-------------------------------------|-------------------------|
| Overfill Drop Tube Valve | OPW 71SOM-412C | Manufacturer Approval | 71SOM_Overfill_Prevention_Valve.pdf | From Permit Application |
| Overfill Drop Tube Valve | OPW 71SOM-412C | Manufacturer Approval | opw overfill prevent drop tubes.pdf | |

Pump Equipment

| Compatibility Item | Model/Manufacturer | Compatibility Method | Documentation | Comment |
|--------------------------|---------------------------|-----------------------|--|---------|
| Submersible Turbine Pump | F.E Petro StpA0150-vI2-00 | Manufacturer Approval | Franklin.pdf | |
| Dispensers | Gilbarco NI1 | Manufacturer Approval | gilbarco dispener e85 certification letter.pdf | |
| Nozzles | Opw 11bp 400691766 | Manufacturer Approval | opw-11bp-series-ethanol-n ozzles_2018.pdf | |
| Swivel | Opw 24tpps | Manufacturer Approval | opw-241tps-series-hose-sw ivels_2018.pdf | |
| Breakaways | Opw 66rec | Manufacturer Approval | opw-66v-series-breakaways _2018.pdf | |

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name Darren White
Job Title Project Manager
Company B&K Equipment
Phone Number (708) 821-5014
Email dj.white@bkequip.com
Contractor License # IL1207

By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.