

**Blended Fuel Compatibility Form**

Facility - 2026784

Facility Name O & S Corp
Address 10007 S. Michigan Avenue
Chicago, IL 60628
County Cook
Contact Name Mohamed Sayed
Phone Number

Tank - 6

Tank Material Fiberglass Double Wall
Tank Capacity 5,000
Tank Product E-85
Tank Install Date 9/4/2019

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	XERXES	Manufacturer Approval	xerxes tanks.pdf	

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Shear Valves	OPW, 10P-0152E85	Manufacturer Approval	opw shear valves....	From Permit Application
Shear Valves	OPW, 10P-0152E85	Manufacturer Approval	opw shear valves....	From Permit Application
Shear Valves	OPW, 10P-0152E85	Manufacturer Approval	opw shear valves....	From Permit Application
Shear Valves	OPW, 10P-0152E85	Manufacturer Approval	opw shear valves....	From Permit Application
Shear Valves	OPW, 10P-0152E85	Manufacturer Approval	opw shear valves....	From Permit Application
Fiberglass Double Wall	Ameron Dualoy 3000/LCX	Manufacturer Approval	ameron fiberglass...	

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	OPW, Pisces series dispenser & pump sump	Manufacturer Approval	opw all products....	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
ATG Probe	846397-407	Manufacturer Approval	veeder root probe...	
Non-Discriminating Interstitial Monitoring Sensors With Monitor	Veeder Root, 794380-345	Manufacturer Approval	veeder root senso...	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Sump Sensor with positive shutdown, dispenser sumps	Veeder Root, 794380-323	Manufacturer Approval	veeder root senso...	From Permit Application
Mechanical Pressurized Line Leak Detection	Vaporless, 99-LD-2000	Manufacturer Approval	vaporless mfg MLL...	
Non-Discriminating Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Veeder Root, 394380-323	Manufacturer Approval	veeder root senso...	

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	OPW 1-2100EVR	Manufacturer Approval	opw all products....	

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW 71SOM-412C	Manufacturer Approval	opw all products....	

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible Pump	402015912-SVL2-12TPAG33	Manufacturer Approval	franklin stp.pdf	
Dispenser	Wayne EB23/5220D3	Manufacturer Approval	wayne dispensers ...	

Gaskets & Seals Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Dispenser	Wayne EB23/4	Manufacturer Approval	wayne dispensers ...	
Pump gaskets	402015912-SVL2-12TPAG33	Manufacturer Approval	franklin stp.pdf	

Joint Dopes & Adhesives Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Thread sealant	Gasolia	Manufacturer Approval	gasolia dope.pdf	
Fiberglass pipe adhesive	NOV Fiberglass Systems	Manufacturer Approval	NOV LCX pipe and ...	

Correspondence Contact

Submitter Name Edward Angell
Job Title Project Manager
Company B&K Equipment Company
Phone Number (708) 474-3344
Email ed@bkequip.com
Contractor License # IL1207

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.