

Certificate of Compliance

Certificate Number 20100604 – MH18037
Report Reference MH18037, 1986 December 15
Issue Date 2010 June 04

Page 1 of 1



Issued to:

OPW FUELING COMPONENTS

**9393 PRINCETON-GLENDALE RD
HAMILTON, OH 45011 USA**

*This is to certify that
representative samples of*

Emergency Breakaway Couplings

Model Descriptions: Emergency breakaway couplings - OPW66V-0492.

Standard(s) for Safety:

*Have been investigated by Underwriters Laboratories Inc.® in accordance
with the Standard(s) indicated on this Certificate.*

**The basic standard used to investigate products in this category is ANSI/UL 567,
"Emergency Breakaway Fittings, Swivel Connectors, and Pipe Connection Fittings
for Petroleum Products and LP-Gas."**

**Products suitable for use with E85 (nominally 15% gasoline/85% ethanol) are
additionally investigated to UL Subject 87A, "Outline of Investigation for Power-
Operated Dispensing Devices for Gasoline/Ethanol Blends Other Than Gasohol
(E10)."**

Additional Information: **See UL On-line Certification Directory at www.ul.com for additional information.**

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product

William R. Carney
Director, North American Certification Programs

Underwriters Laboratories Inc.

Any information and documentation involving UL Mark services are provided on behalf of Underwriters Laboratories Inc. (UL) or any authorized licensee of UL.

For questions, please contact a local UL Customer Service Representative at <http://www.ul.com/global/eng/pages/corporate/contactus/>