

**Blended Fuel Compatibility Form**

Facility - 4033270

Facility Name Casey's General Store
Address 505 East Main Street
Oblong, IL 62449
County Crawford
Contact Name Jill Reams-Widder
Phone Number (515) 965-6238

Tank - 2

Tank Material STIP3 Single Wall
Tank Capacity 6,000
Tank Product E85
Tank Install Date 8/12/1994

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Tank - STIP3 Single Wall	STI-P3 single wall	Manufacturer Approval	SKM_C36821101309520.pdf	

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Flexible Double Wall	XP-175-200SS,XP-200-200SS,STB 175,XP-175-SC,XP-200-SC,STB 200	Manufacturer Approval	FFS-0216 (UL) FFS Product Catalog.pdf	

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Piping - Single Wall STP/Tanktop Sump	FRANKLIN FUELING FIBERGLASS	Manufacturer Approval	catalog-franklin-fueling-systems-apt-piping-containment-systems (1).pdf	
Single Wall UDC Sump	FRANKLIN FUELING POLY	Manufacturer Approval	FFS-0845 Low Profile Dispenser Sump Datasheet.pdf	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Veeder Root	TLS 350	Manufacturer Approval	576047-022.pdf	
ATG Probe	Veeder Root	Manufacturer Approval	577014-449-08_Stainless_Steel_Mag_Plus_In-Tank_Probe_Alternative_Fluids.pdf	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Piping Sump Sensors Not Regulated Not Installed	794380-323	Manufacturer Approval	Position Sensitive Dispenser Pan or Containment Sump Sensor _ Veeder-Root.pdf	Removing from Permit Application.
Sump Sensor with positive shutdown	VEEDER ROOT 794380-323	Manufacturer Approval	Position Sensitive Dispenser Pan or Containment Sump Sensor _ Veeder-Root.pdf	New from Permit Application.
Electronic Pressurized Line Leak Detection	veeder root	Manufacturer Approval	DPLLD 859080 _Electronic_Pressurized_Line_Leak_Detection_Datasheet.pdf	
Piping Sump Sensors Not Regulated Not Installed in Piping - Single Wall STP/Tanktop Sump	not Applicable	Not Applicable		Not Regulated Not Installed

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	705555112CI-GKT	Manufacturer Approval	FFS-0638 (EN) EBW Series Spill Containers Datasheet.pdf	Replacing - Single Wall Spill Bucket from Permit Application.

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	opv 708592902	Manufacturer Approval	ffs-0392-defender-series-overfill-prevention-valve - datasheet.pdf	

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Red Jacket	Red Jacket 1.5 HP AG submersible pump	Manufacturer Approval	SKM_C36821101311500.pdf	

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Gasolia	Gasolia E-Seal Pipe Dope	Manufacturer Approval	SKM_C36821101311520.pdf	

Correspondence Contact

Submitter Name SAMANTHA HUNTER

Job Title CUSTOMER SERVICE COORDINATOR

Company NEUMAYER EQUIPMENT

Phone Number (314) 772-4501

Email testing@neumayerequipment.com

Contractor License # IL1502

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.