

**Blended Fuel Compatibility Form**

Facility - 6044324

Facility Name Love's Travel Stop #384
Address 1900 S. State Route 127
Greenville, IL 62246
County Bond
Contact Name Dave Stewart
Phone Number (405) 302-6640

Tank - 6

Tank Material Fiberglass Double Wall
Tank Capacity 12,000
Tank Install Date 11/5/2009
Current Product on File Gasoline - Regular
Newly Reported Product E98

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	XERXES	Manufacturer Approval		

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Ameron Dualoy 3000/LCX	Manufacturer Approval		

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Blending Sump	Bravo Sump	Manufacturer Approval		
Single Wall STP/Tanktop Sump	Bravo Sump	Manufacturer Approval		
Single Wall UDC Sump	Bravo UDC	Manufacturer Approval		

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensors With Monitor	Franklin Fueling FMP-E1S	Manufacturer Approval		
ATG Probe	Franklin Fueling FMP-LL3-125-1	Manufacturer Approval		

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Franklin Fueling - INC-TS-ELLD	Manufacturer Approval		
Sump Sensor in Single Wall STP/Tanktop Sump	Franklin Fueling FMP-ULS	Manufacturer Approval		

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	Franklin Fueling - EBW L 705545011CI-GKT	Manufacturer Approval		

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	Franklin Fueling - EBW L 708692922	Manufacturer Approval		
Overfill Alarm	Franklin Fueling - INC TS-RA1	Manufacturer Approval		

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible Turbine Pump	Franklin Fueling FEP L 402568924-2HP	Manufacturer Approval		

Gaskets & Seals Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Seals / Gaskets	Viton	Manufacturer Approval		

Joint Dopes & Adhesives Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Dope	Gasolia	Manufacturer Approval		

Correspondence Contact

Submitter Name Anthony Mannino
Job Title Project Coordinator
Company Illinois Oil Marketing Equipment
Phone Number (309) 202-0792
Email amannino@iome.com
Contractor License # IL1293

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.