

**Blended Fuel Compatibility Form****Facility - New**

Facility Name Woodman's Store #30
Address 3166 McFarland Road
Rockford, IL 61114
County Winnebago
Contact Name Jacob Bishop
Phone Number (815) 986-0220

Tank - 3

Tank Material Tank - Fiberglass Double Wall
XERXES
Tank Capacity 6,000
Tank Product E85
Tank Install Date Not Installed

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	XERXES Fiberglass	Manufacturer Approval	Xerxes E85 Compat.pdf	New from Permit Application.

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Ball Valves	Franklin Fueling	Manufacturer Approval	21BV_Full_Port_Ball_Valve.pdf	New from Permit Application.
Other Pump	Submersible	Manufacturer Approval	FE Petro compatibility statement IST.pdf	New from Permit Application.
Flex Connector Steel	FE PETro	Manufacturer Approval	E85 Flex Connector Frankl in Fueling.pdf	New from Permit Application.
Flexible Double Wall	Franklin Fueling Systems UPP	Manufacturer Approval	E85 UPP+pipe.pdf	New from Permit Application.
Shear Valves	OPW	Manufacturer Approval	E85 OPW compatibility10 series emergency valve.pdf	New from Permit Application.

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	S Bravo	Manufacturer Approval	Bravo_Sumps_AlternativeFuels_R3 (1).pdf	New from Permit Application.
Single Wall UDC	Franklin Fueling APT	Manufacturer Approval	E85 UDC Disp Containment Franklin.pdf	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensors	Franklin Fueling	Manufacturer Approval	E85 EVO Incon Probes & Sensors.pdf	New from Permit Application.
ATG Probe	Franklin Fueling	Manufacturer Approval	E85 EVO Incon Probes & Sensors.pdf	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Franklin Fueling	Manufacturer Approval	E85 EVO Line Leak.pdf	New from Permit Application.
Sump Sensor with positive shutdown	Franklin Fueling	Manufacturer Approval	E85 EVO Incon Probes & Sensors.pdf	New from Permit Application.

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	Franklin Fueling	Manufacturer Approval	E85 Defender Series Spill Containers Datasheet.pdf	New from Permit Application.

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Alarm	Franklin Fueling	Manufacturer Approval	E85 EVO Incon Probes & Sensors.pdf	New from Permit Application.
Overfill Drop Tube Valve	OPW	Manufacturer Approval	71SOM_Overfill_Prevention_Valve.pdf	New from Permit Application.

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Dispenser MPD	Wayne	Manufacturer Approval	E85 wayne-ovation2-fuel-dispenser-.pdf	
Submersible Turbine Pump	FE Petro	Manufacturer Approval	E85 submersible info sheet.pdf	
Nozzle	OPW	Manufacturer Approval	e85 Huskey Nozzle.pdf	
Hose	Flexsteel Futura	Manufacturer Approval	E85 Compat hose.pdf	

Gaskets & Seals Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Pipe Dope	Gasoila	Manufacturer Approval	E85 Gaseola.pdf	

Joint Dopes & Adhesives Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Dope	Gasoila	Manufacturer Approval	E85 Gaseola.pdf	

Correspondence Contact

Submitter Name

Job Title

Company

Phone Number

Email

Contractor License #

Robert Sumoski

President

Crowne Industries, Ltd.

(630) 201-4967

bob@crownetank.com

IL002345

☒

By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.