

**Blended Fuel Compatibility Form**

Facility - 2044529

**Facility Name** Circle K #6870  
**Address** 2832 S. Route 59  
Naperville, IL 60564  
**County** Du Page  
**Contact Name** Aqpril Pitts  
**Phone Number** (630) 548-5407

Tank - 2

**Tank Material** Fiberglass Double Wall  
**Tank Capacity** 8,000  
**Tank Product** E-85  
**Tank Install Date** 12/9/2009

**Tank Equipment**

| Compatibility Item                   | Model/Manufacturer | Compatibility Method  | Documentation | Comment |
|--------------------------------------|--------------------|-----------------------|---------------|---------|
| Tank - Fiberglass Double Wall XERXES | XERXES             | Manufacturer Approval | E85 all.pdf   |         |

**Piping Equipment**

| Compatibility Item                          | Model/Manufacturer | Compatibility Method  | Documentation | Comment |
|---------------------------------------------|--------------------|-----------------------|---------------|---------|
| Piping - Flexible Double Wall OPW Flexworks | OPW Flexworks      | Manufacturer Approval | E85 all.pdf   |         |

**Containment Sump Equipment**

| Compatibility Item                            | Model/Manufacturer | Compatibility Method  | Documentation | Comment |
|-----------------------------------------------|--------------------|-----------------------|---------------|---------|
| Piping - Single Wall STP/Tanktop Sump and UDC | opw                | Manufacturer Approval | E85 all.pdf   |         |

**Release Detection Tank Equipment**

| Compatibility Item                                                      | Model/Manufacturer     | Compatibility Method | Documentation        | Comment |
|-------------------------------------------------------------------------|------------------------|----------------------|----------------------|---------|
| ATG Probe                                                               | Veeder Root 846391-410 | Lab Certification    | e85 veeder probe.pdf |         |
| Leak Detect - Tank - Non-Discriminating Interstitial Monitoring Sensors | Veeder Root 794380-345 | Lab Certification    | E85 sensors.pdf      |         |

**Release Detection Piping Equipment**

| Compatibility Item  | Model/Manufacturer     | Compatibility Method | Documentation   | Comment                   |
|---------------------|------------------------|----------------------|-----------------|---------------------------|
| Veeder Root Sensors | Veeder Root 794380-345 | Lab Certification    | E85 sensors.pdf | The sensors and the elld. |

**Spill Prevention Equipment**

| Compatibility Item       | Model/Manufacturer | Compatibility Method  | Documentation | Comment |
|--------------------------|--------------------|-----------------------|---------------|---------|
| Double Wall Spill Bucket | emco               | Manufacturer Approval | E85 Emco.pdf  |         |

**Overfill Prevention Equipment**

| Compatibility Item                              | Model/Manufacturer | Compatibility Method  | Documentation         | Comment                                 |
|-------------------------------------------------|--------------------|-----------------------|-----------------------|-----------------------------------------|
| Overfill Prev Device - Overfill Drop Tube Valve | emco               | Manufacturer Approval | E85 Emco.pdf          | From Permit Application                 |
| Ball Only Removed Ball Float Vent Valve         | opw                | Not Applicable        |                       | NA this is being removed not installed. |
| Overfill Alarm                                  | veeder Root        | Manufacturer Approval | e85 veeder sensor.pdf |                                         |
| Overfill Drop Tube Valve                        | emco               | Manufacturer Approval | E85 Emco.pdf          |                                         |

#### Pump Equipment

| Compatibility Item | Model/Manufacturer | Compatibility Method | Documentation | Comment |
|--------------------|--------------------|----------------------|---------------|---------|
| Gilbarco           | E700 S             | Lab Certification    | E85 all.pdf   |         |

#### Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

#### Joint Dopes & Adhesives Equipment

| Compatibility Item        | Model/Manufacturer | Compatibility Method  | Documentation | Comment |
|---------------------------|--------------------|-----------------------|---------------|---------|
| Gasolila E Seal Pipe dope | Gasolila E Seal    | Manufacturer Approval | e85 dope.pdf  |         |

#### Correspondence Contact

**Submitter Name** Stephen Kryl  
**Job Title** Project manager  
**Company** Anderson Pump Service  
**Phone Number** (708) 243-9081  
**Email** steve@andersonpump.com  
**Contractor License #** IL002275

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.