



Blended Fuel Compatibility Form

Facility - 2006920

Facility Name Hickory Hills Food Mart
Address 9459 S. Roberts Rd.
 Hickory Hills, IL 60457
County Cook
Contact Name Syed Moinuddin
Phone Number (708) 598-5353

Tank - 3

Tank Material Fiberglass Single Wall
Tank Capacity 8,000
Tank Product E85
Tank Install Date 1/1/1970

Tank Equipment

| Compatibility Item | Model/Manufacturer | Compatibility Method | Documentation | Comment |
|---------------------------|--|-----------------------|--|--|
| Fiberglass Single Wall | Owens Corning | Manufacturer Approval | Owens Corning 4-14-95 document on alcohol warranties by date.pdf | Tank has been lined for compatibility. |
| Lining Materials Internal | Bridgeport Chemical Glass Armor GA 27P | Manufacturer Approval | bridgeport tank lining.pdf | |

Piping Equipment

| Compatibility Item | Model/Manufacturer | Compatibility Method | Documentation | Comment |
|-------------------------------|--------------------|-----------------------|--|--------------------------------------|
| Shear Valve | Opw 10 plus | Manufacturer Approval | OPW 10_Plus_Series_Emergency_Shut-Off_Valves.pdf | INSTALLING ON DISPENSERS 1,2-3,4-7,8 |
| Single wall Fiberglass piping | Ameron | Manufacturer Approval | Ameron Pipe Compatibility Statement.pdf | INSTALLING ON DISPENSERS 1,2-3,4-7,8 |

Containment Sump Equipment

| Compatibility Item | Model/Manufacturer | Compatibility Method | Documentation | Comment |
|----------------------|--------------------|-----------------------|--|--------------------------------------|
| Single Wall UDC Sump | BRAVO B402 | Manufacturer Approval | Bravo Sump Compatibility Statement.pdf | INSTALLING ON DISPENSERS 1,2-3,4-7,8 |

Release Detection Tank Equipment

| Compatibility Item | Model/Manufacturer | Compatibility Method | Documentation | Comment |
|--------------------|--------------------|-----------------------|---------------------------------------|---------|
| ATG Probe | Veeder-Root | Manufacturer Approval | Veeder Root E85 probe 577 013-054.pdf | |

Release Detection Piping Equipment

| Compatibility Item | Model/Manufacturer | Compatibility Method | Documentation | Comment |
|--|--------------------|-----------------------|----------------------|---------|
| Electronic Pressurized Line Leak Detection | Veeder-Root PLLD | Manufacturer Approval | Veeder Root PLLD.pdf | |

Spill Prevention Equipment

| Compatibility Item | Model/Manufacturer | Compatibility Method | Documentation | Comment |
|-------------------------|--------------------|-----------------------|---|---------|
| DOUBLWALL SPILL BUCKETS | OPW 3100 | Manufacturer Approval | OPW Belowground Product Compatibility Listing 0715 18.pdf | |

Overfill Prevention Equipment

| Compatibility Item | Model/Manufacturer | Compatibility Method | Documentation | Comment |
|--------------------|--------------------|-----------------------|---|---------|
| OVERFILL DROP TUBE | OPW71SOM | Manufacturer Approval | OPW 71SOM_Overfill_Prevention_Valve.pdf | |

Pump Equipment

| Compatibility Item | Model/Manufacturer | Compatibility Method | Documentation | Comment |
|--------------------------|--------------------|-----------------------|---|---------|
| Submersible Turbine Pump | FE Petro | Manufacturer Approval | FE PETRO STPAPM200-VL2ff s-0412-60-hz-advanced-pro tection-submersible-turbi ne-pumps-datasheet.pdf | |
| Dispenser | Wayne Ovation | Manufacturer Approval | WAYNE MH1821-45-6 Ovation CertificateofCompliance. pdf | |
| Nozzle | OPW | Manufacturer Approval | OPW 11a-and-11b-automatic -nozzles.pdf | |
| Hose | Goodyear | Manufacturer Approval | Goodyear E85 Ethanol hose .pdf | |

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

| Compatibility Item | Model/Manufacturer | Compatibility Method | Documentation | Comment |
|--------------------|--------------------|-----------------------|-------------------|---------|
| PIPE DOPE | GASOILA | Manufacturer Approval | Gasoil E-Seal.pdf | |

Correspondence Contact

Submitter Name CHRIS DERRO

Job Title PRESIDENT

Company Cardinal Compliance LLC

Phone Number (708) 717-2676

Email CDERRO@CARDINALCOMPLIANCE.NET

Contractor License # IL002418

By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.