



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL

Blended Fuel Compatibility Form

Facility - 2006926

Facility Name Joliet Food Mart, Inc.
Address 4230 W. Jefferson St.
Joliet, IL 60435
County Will
Contact Name Abdul Basit
Phone Number (815) 744-5777

Tank - 7

Tank Material Fiberglass Double Wall
Tank Capacity 7,000
Tank Install Date 4/7/2011
Current Product on File Low Sulfur Diesel
Newly Reported Product E-85

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Containment Solutions	Manufacturer Approval	CSI-compatibility.pdf	

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Flexible Double Wall	NUPI Smartflex	Manufacturer Approval	other-equipment-compatibility.pdf	

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	Petroleum Containment Inc	Manufacturer Approval	pci-biodiesel.pdf	
Single Wall UDC	Petroleum Containment Inc	Manufacturer Approval	pci-biodiesel.pdf	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensors	Veeder Root-794380-345	Manufacturer Approval	577013-750-13_Solid-State Alternative Ethanol Fluid Interstitial Sensor_for _Double-Wall_Fiberglass_Tanks.pdf	
ATG Probe	Veeder Root-846397-407	Manufacturer Approval	577014-449-08_Stainless Steel_Mag_Plus_In-Tank_Probe_Alternative_Fluids.pdf	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder Root-859080-001	Manufacturer Approval	576047-319_Electronic_Pressurized_Line_Leak_Detection_Datasheet.pdf	
Non-Discriminating Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Veeder Root-794380-323	Manufacturer Approval	577013-750-10_Position_Sensitive_Sensor.pdf	

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	OPW-1C-2100C	Manufacturer Approval	opw-fuel-compatibility-matrix-below-ground-products-2018.pdf	

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW-71SOM	Manufacturer Approval	71SO_Overfill_Prevention_Valve.pdf	

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Gilbarco Dispenser	Encore Series	Manufacturer Approval	Encore Flex Fuel Dispenser _ Gilbarco Veeder-Root.pdf	

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name Ravindra Penmatsa
Job Title President
Company Ampsco Services
Phone Number (312) 286-6722
Email ravi@ampsco.net
Contractor License # IL002420

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.