

**Blended Fuel Compatibility Form**

Facility - 2046836

Facility Name Thornton's #330
Address 3503 S. Cicero
Cicero, IL 60804
County Cook
Contact Name Yeci Esquivel
Phone Number (708) 652-6539

Tank - 6

Tank Material Fiberglass Double Wall
Tank Capacity 6,000
Tank Product E85
Tank Install Date 9/20/2019

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Containment Solutions Double Wall with Brine	Manufacturer Approval	2 +Tank+Sumps+CSI.pdf	

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Ameron Dualoy 3000/LCX	Manufacturer Approval	3+Piping.pdf	

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Dispenser Sump	Bravo	Manufacturer Approval	4+UDC+Bravo.pdf	
Single Wall STP/Tanktop Sump	Containment Solutions SW Fiberglass Tank Sumps	Manufacturer Approval	2 +Tank+Sumps+CSI.pdf	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
ATG Probe	Veeder Root 846391-410	Manufacturer Approval	5+Probe+Float.pdf	
Hydrostatic Reservoir Interstitial Monitoring Sensors	Veeder Root 794380-303	Manufacturer Approval	6+Sensors+VR323+VR303.pdf	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder Root 848480-003	Manufacturer Approval	7+E85+Compatibility+TLS+Products.pdf	
Non-Discriminating Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Veeder Root 794380-323	Manufacturer Approval	6+Sensors+VR323+VR303.pdf	

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	Spill Bucket	Manufacturer Approval	Franklin Fueling Sumps, Spill Buckets, Fittings.pdf	

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW 71SOM-412C	Manufacturer Approval	9+Overfill+Prevention+Valve+OPW.pdf	

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Pump	Franklin Fueling IST	Manufacturer Approval	10+Pump+Franklin.pdf	

Gaskets & Seals Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Gaskets & Seals	Wayne Dispensers Helix	Manufacturer Approval	11+Dispenser+Meter+Wayne.pdf	

Joint Dopes & Adhesives Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Joint Dopes & Adhesives	Gasolia E-Seal	Manufacturer Approval	12+Gasolia.pdf	

Correspondence Contact

Submitter Name Amber Pena
Job Title Director of Service
Company Stenstrom Petroleum Services Group
Phone Number (815) 398-6250
Email amberp@rstenstrom.com
Contractor License # IL1890

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.