



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL

Blended Fuel Compatibility Form

Facility - 6045344

Facility Name Pilot Travel Center #1225

Address 9810 Perrin Rd.
Rt.4 @ I-64
Mascoutah, IL 62224

County St. Clair

Contact Name Joey Cupp

Phone Number (865) 588-7488

Tank - 6

Tank Material Fiberglass Double Wall

Tank Capacity 20,000

Tank Product B-99

Tank Install Date 4/1/2020

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	XERXES	Lab Certification		

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Ameron Dualoy 3000/LCX	Lab Certification		
Fiberglass Single Wall Piping	Ameron Dualoy 3000L	Lab Certification		
Aboveground	Ferguson Steel Piping and Valves	Manufacturer Approval		
Flex Connector	Omega Flex Connector	Manufacturer Approval		
Shear Valve	OPW 10 Series	Manufacturer Approval		

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Transition Sump	Bravo B8XX	Lab Certification		
Blending Sump	Painted Rhino	Manufacturer Approval		
Single Wall STP/Tanktop Sump	Bravo B4XX	Lab Certification		

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensors	794380-345	Manufacturer Approval		
ATG Probe	8463x1	Manufacturer Approval		

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
European with No Test Req Suction	N/A	Not Applicable		N/A
Non-Discriminating Sump Sensor with positive shutdown in Single Wall Transition Sump	794380-321	Manufacturer Approval		

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	794380-321	Manufacturer Approval		

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	OPW 1c-3112d	Manufacturer Approval		

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	Franklin Defender Series	Manufacturer Approval		

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fuel Dispenser	Gilbarco Encore	Lab Certification		
Bio Suction Pump	Groman Rupp GHS2P3-B/S1	Manufacturer Approval		
Dispenser Hose Assembly	Husky Hose Assembly 014559	Manufacturer Approval		

Gaskets & Seals Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Gasket	Ferguson Teflon Gasket	Manufacturer Approval		

Joint Dopes & Adhesives Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Piping Epoxy	NOV PSX	Manufacturer Approval		

Correspondence Contact

Submitter Name Alex Griffith

Job Title PM

Company Neumayer Equipment Company, Inc.

Phone Number (314) 712-2603

Email alex_griffith@neumayerequipment.com

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.