



### Blended Fuel Compatibility Form

Facility - 2045867

<b>Facility Name</b>	Thornton's #316
<b>Address</b>	2095 E. Algonquin Road Algonquin, IL 60102
<b>County</b>	Kane
<b>Contact Name</b>	Patty Leonhardt
<b>Phone Number</b>	

Tank - 4

<b>Tank Material</b>	Fiberglass Brine Filled Double Wall
<b>Tank Capacity</b>	6,000
<b>Tank Product</b>	E85
<b>Tank Install Date</b>	6/5/2015

#### Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Brine Filled Double Wall	Containment Solutions Double Wall with Brine	Manufacturer Approval	2 +Tank+Sumps+CSI.pdf	

#### Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Ameron Dualoy 3000/LCX	Manufacturer Approval	3+Piping.pdf	

#### Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Dispenser Sump	Bravo	Manufacturer Approval	4+UDC+Bravo.pdf	
Single Wall STP/Tanktop Sump	Containment Solutions SW Fiberglass Tank Sumps	Manufacturer Approval	2 +Tank+Sumps+CSI.pdf	

#### Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
ATG Probe	Veeder Root 846391-410	Manufacturer Approval	5+Probe+Float.pdf	
Required Other Monitor only for sensors	Veeder Root TLS 450 Plus	Manufacturer Approval	Veeder Root Sump & Inters tial Sensors.pdf	Replacing from Permit Application.

#### Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	EPLLD	Manufacturer Approval	Veeder Root Electronic Le ak Detector.pdf	Replacing from Permit Application.
Non-Discriminating Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Veeder Root 794380-323	Manufacturer Approval	6+Sensors+VR323+VR303.pdf	

#### Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	Franklin Fueling Defender 705	Manufacturer Approval	8+Spill+Bucket+Franklin.p df	

#### Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	71SOM-412C	Manufacturer Approval	OPW Overfill Prevention Valve.pdf	

### Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Pump	Franklin Fueling IST	Manufacturer Approval	10+Pump+Franklin.pdf	

### Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

### Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

#### Correspondence Contact

**Submitter Name** Amber Pena  
**Job Title** Director of Service  
**Company** Stenstrom Petroleum Services Group  
**Phone Number** (815) 398-6250  
**Email** amberp@rstenstrom.com  
**Contractor License #** IL1890

By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.