

**Blended Fuel Compatibility Form**

Facility - 2043595

Facility Name Fuller BP
Address 13501 South Kedzie Avenue
Robbins, IL 60472
County Cook
Contact Name Tarek "Terry" Rifai
Phone Number (708) 388-6000

Tank - 2

Tank Material Fiberglass Double Wall
Tank Capacity 4,000
Tank Product E-85
Tank Install Date 1/24/2008

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Xerxes	Manufacturer Approval	xerxes tanks.pdf	

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Flexible Double Wall	OPW Flexworks	Manufacturer Approval	E85 opw flexworks.pdf	

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Under dispenser containment	APT	Manufacturer Approval	APT Sumps E85 Compatibility Letter 08.07.19.pdf	
Single Wall STP/Tanktop Sump	Xerxes single wall fiberglass	Manufacturer Approval	xerxes attached sumps.pdf	
Single Wall UDC Sump	apt	Manufacturer Approval	APT UDC.pdf	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
ATG Probe	Veeder-Root	Manufacturer Approval	veeder root probes.pdf	
Non-Discriminating Interstitial Monitoring Sensors	Veeder-Root	Manufacturer Approval	veeder root sensors all.pdf	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Mechanical Pressurized Line Leak Detection	Franklin MLLD	Manufacturer Approval	franklin mllld.pdf	
Non-Discriminating Sump Sensor in Single Wall STP/Tanktop Sump	Veeder-Root	Manufacturer Approval	veeder root sensors all.pdf	

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	Emco Wheaton	Manufacturer Approval	Emco A1004 & 1005 containers.pdf	

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	Emco Wheaton	Manufacturer Approval	EMCO A1100 Overfill Prevention Valve.pdf	

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
FE Petro 150AG	Franklin Fueling	Manufacturer Approval	E85 submersible info sheet.pdf	

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact		☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.
Submitter Name	Stephen Kryl	
Job Title	Project Manager	
Company	Anderson Pump Service, Inc.	
Phone Number	(708) 243-9081	
Email	stevekryl@aol.com	
Contractor License #	IL002275	